

This document is classified as **White** in accordance with the Panel Information Policy. Information can be shared with the public, and any members may publish the information, subject to copyright.



**SECMP0062**  
**‘Northbound Application Traffic  
Management – Alert Storm  
Protection’**

**Modification Report**  
**Version 3.0**

## About this document

---

This document is the Modification Report for [SECMP0062 'Northbound Application Traffic Management – Alert Storm Protection'](#). It provides detailed information on the background, issue, solution, costs, impacts and implementation approach. It also summarises the discussions that have been held and the conclusions reached with respect to this Modification Proposal.

## Contents

---

1. Summary.....	3
2. Background.....	4
3. Solution.....	6
4. Impacts.....	9
5. Costs.....	11
6. Implementation approach.....	12
7. Discussions and development.....	13
8. Conclusions.....	17
Appendix 1: DCC Systems changes.....	20
Appendix 2: Glossary.....	21

This document has seven annexes:

- **Annex A** contains the business requirements for the proposed solution.
- **Annex B** will contain the redlined changes to the Smart Energy Code (SEC) required to deliver the proposed solution. This document is currently being updated.
- **Annex C** contains the 'Traffic Management Mechanism Document' which will be introduced as part of this modification.
- **Annex D** contains the full Data Communications Company (DCC) Impact Assessment response.
- **Annex E** contains the Working Group Consultation responses.
- **Annex F** contains the first Modification Report Consultation responses.
- **Annex G** contains the second Modification Report Consultation responses.

## 1. Summary

---

Alert Storms occur when Devices repeatedly send Alerts to DCC Systems and Service Users. Although these Devices have gone through rigorous test assurance processes, it is inevitable that not every possible combination and scenario will have been accounted for. This means that many Devices pose a risk of entering a state whereby they repeatedly and rapidly generate the same Device Alert, adding unnecessary traffic to the Communication Service Provider (CSP) or Smart Metering Equipment Technical Specification (SMETS) 1 Service Provider (S1SP) Gateway between the DCC Systems and Service Users. Currently there is little protection against Alert Storms, meaning that multiple Alerts are being counted and entering the gateway, rather than being filtered out, even after recognising they are originating from the same single Device.

In December 2019 the DCC stated that the original system had been designed and built to a contracted capacity of one Alert per Device per month, which was what was estimated when the system was designed. However, actual figures showed 43 million Alerts had originated from 4 million meters on 31 December 2019 alone, with 1.3 billion Alerts across the month of December 2019.

The proposed solution is to provide Alert Storm protection through a DCC designed mechanism which will count the number of Alerts originating from a specific, individual Device within a defined time window. If the Device sends the same Alert above a pre-determined threshold value, the mechanism will consolidate excess Alerts from the Device and only forward one copy of that Alert in a designated period agreed by the DCC on to the intended Users. Consolidated Alerts will be counted for Anomaly Detection purposes and Service Users will be notified ahead of time for the exact actions being taken. This solution will be implemented over two stages.

This modification will impact Supplier Parties, Network Parties, Other SEC Parties and the DCC. The total cost of implementation for this modification will be £1,088,392. The proposed implementation date for this modification is the June 2020 SEC Release for the core solution and the November 2020 SEC Release for the DCC User Interface Specification (DUIS) changes.

## 2. Background

---

### Context to DCC Systems Communications

The DCC and Service Users communicate using the DCC Systems to send service requests and Alerts for different registered Devices. Due to the DCC System having a finite capacity for how many requests and Alerts it can handle, if this system becomes overloaded, it will affect the stability and performance of the whole system. This system could also be subject to Alert Storms, a state where individual Devices may frequently generate the same Alert and send it through the DCC Systems. This adds needless traffic to the DCC Systems and, as a result, slows down the response time for other Alerts and service requests. Alert Storms therefore need to be avoided as much as possible, or alternatively, traffic management needs to be in place to prevent repeated Alerts from a faulty Device entering multiple Alerts into the system.

### What is the issue?

Alert Storms are one of the biggest issues faced by the DCC with its systems for handling service requests and Alerts from Service Users. Currently, the DCC uses a detection solution for northbound traffic (traffic passing from Devices to Users) which follows a pattern where Alerts are counted over a specified time window. If the total number of Alerts exceeds a pre-determined threshold (which is defined by either amber or red levels) the event is recorded in the security log and an incident file is saved.

However, this solution does not prevent the Alerts from being forwarded to the relevant Service Users, so therefore does not protect the DCC Systems against overload or traffic generated by Alert Storms. In December 2019 the DCC stated that the original system had been designed and built to a contracted capacity of one Alert per Device per month, which was what was estimated when the system was designed. However, actual figures showed 43 million Alerts had originated from 4 million meters on 31 December 2019 alone, and a total of 1.3 billion Alerts for the month of December 2019. The DCC reported that Alert traffic was currently doubling every three months, and this would increase as the rollout continued to unmanageable levels.

Whilst the DCC's aim is to manage Alerts at the Communications Hub in future, this is not currently possible and will need development time of an estimated 24-36 months. In the meantime, a solution is needed to manage the Alerts traffic. The DCC thereby needs to take direct action to protect its systems to ensure availability of the service for its Service Users and incorporate a new means of traffic management to prevent, where possible, excess Alerts from entering its system.

### Breakdown of SMETS1 and SMETS2 Alerts impacting the DCC Systems

A question was raised around the level of SMETS1 Alerts and how they are affecting the DCC Systems currently, and whether the DCC System was designed to deal with the number of Alerts it is currently experiencing. The DCC responded that the number of SMETS1 Alerts are much lower than the number of SMETS2 Alerts. It stated that Alert volumes, as set out in the original 'Invitation to Submit Final Tender' (ISFT) contracts awarded by the Department of Energy and Climate Change (DECC), requires service users to scale to meet an average profile of 0.04 Device Alerts per meter per day. On 13 November 2019, SMETS1 meters generated on average six Device Alerts per meter per day (150 x the ISFT Profile); a volume significantly higher than the ISFT profile. On the same day

for SMETS2 an average of 12 Device Alerts were generated per meter per day (300 x the ISFT profile). These are summarised in the graph below.

The Device Alert volumes for SMETS2 not only exceed the contracted volumes as described above, but with a small number of Devices each responsible for thousands of device alerts per day, this geographically concentrates traffic on the CSP networks, compounding the problems caused by device alerts.

In summary:

- SMETS1 Alerts are more geographically distributed and dispersed across five SMETS1 Alert codes, whereas 80% of SMETS2 alerts are accounted for by a single Alert code (8F3E – unauthorised access) and the majority are generated by a small number of devices
- The number of Alerts varies by Service User. The Service User receiving the most device alerts, receives them at a rate 1,000 times greater than contracted rate per meter per day.

Device Alert Per Meter Per Day



### 3. Solution

---

#### Proposed Solution

The proposed solution is to provide Alert Storm protection through a DCC designed mechanism which will count the number of Alerts originating from a specific Device within a designated timeframe. If the Device sends Alerts above a pre-determined threshold value, the mechanism will consolidate excess Alerts from the Device, and only forward one per a configurable number of Alerts (n) per designated period on to the intended Users. Consolidated Alerts will be counted for Anomaly Detection purposes and Service Users will be notified ahead of time for the exact actions being taken.

A visual summary of the impacts on the DCC Systems can be found in Appendix 1. The business requirements for this solution can be found in Annex A.

#### How will the mechanism operate?

The mechanism operates by periodically checking the total number of Alerts generated by a Device to see if it exceeds a “red” threshold. This is the point at which too many (a value defined by the DCC in the Traffic Management Mechanism Document in Annex C) Alerts are being received from that specific Device, triggering the solution’s mechanism. This will be known as “red” in terms of Alert thresholds. If a “red” threshold anomaly is detected at the Device level, the mechanism then counts each specified Alert Code. If the count of a specific Alert Code exceeds the ‘Alert Code Specific Threshold’ within the ‘Alert Code Specific Rolling Window’ then the code will be marked as “HighAlertRate” and subject to consolidation. It is noted that if an Alert Code is consolidated at Device level, this only affects the Devices generating the Alerts that exceed the threshold. Any Devices that are not exceeding the threshold but still generating those Alerts will not be subject to having their Alerts counted and consolidated.

The DCC has confirmed that these Alert Code settings are “global”, meaning the threshold is the same for all Alert Codes and can’t be tailored on an individual basis. This was justified because configuration in that area would add expense and time to the development of the solution.

The parameters to this mechanism will be fully configurable, for example the Alert Code threshold, the number of consolidated Alerts and a “rolling window” indicating how long an incident would last. These parameters will be recorded in the Traffic Management Mechanism Document. Any changes to these parameters will be managed by the Operations Group.

If an Alert Code isn’t marked as “HighAlertRate” it is passed on to Request Management as normal. If an Alert Code is “HighAlertRate” then it will be subject to consolidation and only one in n Alerts will be forwarded to Request Management, together with the count of the consolidated Alerts. Once the number of Alerts falls below the “red” threshold, then that specific Alert Code counting will cease, and any “HighAlertRate” Alert Codes will be cleared.

#### How will the solution be implemented?

This solution will be implemented in two stages:

- The first stage (Part 1) will have a single default value for Alert Code thresholds, which will be configured using a basic configuration file similar to that currently used for more generic Alert Anomaly Detection Thresholds. It will also have an exclusion list of Alert Codes which will be exempted from this mechanism. This list of Alert Codes will be managed by the Panel; the

Working Group agreed with the Smart Energy Code Administrator and Secretariat (SECAS) recommendation that this responsibility should be delegated to the Operations Group. This results in an Alert either being subject to a configurable but global traffic management setting or exempted from this traffic management.

During this stage, a new dashboard in the Self-Service Interface (SSI) will show Service Users whether any Alert Storm Protection is currently active for any of their Devices; this will be defined and designed via the SSI update process following approval of SECMP0062. The DCC's Technical Operations Centre (TOC) will be utilised to provide reporting based on additional data feeds from the proposed solution. The TOC can provide data approximately 15 minutes behind real time, allowing it to indicate trends for DCC System traffic – this data will be used by DCC to help identify root causes of Alert Storms where possible.

Alert consolidation can be used to create Incidents within the DCC Service Management System (DSMS); this will be a system configuration parameter. The DSMS enables Users to elect to receive email notifications when incidents are created.

- The second stage (Part 2) of the solution will introduce DUIS Schema changes (these changes are defined more explicitly as part of the DCC Impact Assessment in Annex D). The Alerts will have metadata in their headers to distinguish between an Alert that has or hasn't been subject to Alert Storm Protection. The DUIS changes will only be included in the new version of DUIS created in the relevant SEC Release, and will not apply to previous versions.

## How will Incidents be managed under Part 1 of the solution?

The solution includes a system configuration parameter to allow the creation of a DSMS Incident whenever consolidation is first initiated for a specific Device/Alert Code combination. This incident would be allocated to the Known Remote Party for that Device/Alert Code as defined in the GBCS.

Any Alert Code in the exclusion list will never be subject to Alert Storm Protection. A full list has been discussed and agreed with Service Users (see Annex C), and any future changes would be managed by the Panel.

No new incident would be created for the same Device/Alert Code combination until it has remained below the threshold for longer than the 'Alert Storm Protection Incident Deadband Period'.

The configuration parameter 'Alert Storm Protection Incident Creation' operates system-wide and so is a single setting that will affect all Users.

Due to the current Alert volumes, this will be configured 'OFF' when Part 1 goes live, until such time as (a) Alert volumes have returned to more reasonable levels, and (b) Users are in agreement that they wish this to be enabled. As the ON/OFF settings will be recorded in the Traffic Management Mechanism Document, changes to this must be agreed with the Panel (or a Sub-Committee nominated by it) before they take effect.

## How will email notification be managed under Part 1 of the solution?

Email notifications of incidents are an existing feature of the DSMS. Users can elect to enable or disable this feature, but it does operate across all Incidents allocated to that User, not just those originating from the Alert Storm Protection solution.

As stated above, incident creation will be turned off initially, to avoid Users receiving large numbers of emails once SECMP0062 is implemented.

### Legal text

The changes to the SEC required to deliver the proposed solution will be found in Annex B. The 'Traffic Management Mechanism Document' cited in the legal text can be found in Annex C.

## 4. Impacts

This section summarises the impacts that would arise from the implementation of this modification.

### SEC Parties

SEC Party Categories impacted			
✓	Large Suppliers	✓	Small Suppliers
✓	Electricity Network Operators	✓	Gas Network Operators
✓	Other SEC Parties	✓	DCC

All SEC Parties will be subject to the effects of the throttling effects and consolidation of Alerts, and will therefore need to manage any resulting reporting of this accordingly. Following the Working Group Consultation sent out to SEC Parties, one respondent cited they would incur additional costs in developing their internal systems and processes to accept the changes proposed under this modification and that they would require a minimum of six months lead time to uplift their systems and add functionality changes.

Following the Modification Report Consultation, Electricity Network Parties expressed concerns as to how the reporting would be managed and that they would suffer administrative issues through Part 1 of the solution. Clarifications were made to the reporting following this and SECAS agreed with the DCC that the email notification of alerts and incidents could be turned off initially so that email notifications would not cause administrative issues for Users.

### DCC System

The DCC Systems will be impacted due to adding the mechanism which delivers the solution set out in this Modification Proposal. However, if this modification is not implemented the stability and performance of the DCC Systems will be at risk and the response times for other Alerts and service requests will slow down.

The full impacts on the DCC Systems and DCC's proposed testing approach can be found in the DCC Impact Assessment response in Annex D.

### SEC and subsidiary documents

The following parts of the SEC will be impacted by Part 1:

- Section H 'DCC Services'
- Appendix AB 'Service Request Processing Document'
- Appendix AH 'Self Service Interface Design Specification'

The following part of the SEC will be impacted by Part 2:

- Appendix AD 'DCC User Interface Specification'

### **Other industry Codes**

No other Energy Codes will be impacted by this modification.

### **Greenhouse gas emissions**

Greenhouse gas emissions will not be impacted.

## 5. Costs

### DCC costs

The confirmed DCC implementation costs to deliver this modification is £1,088,392. The breakdown of these costs are as follows:

Breakdown of DCC implementation costs	
Activity	Total
Design	£964,346
Build	
Pre-Integration Testing (PIT)	
Systems Integration Testing (SIT)	£96,995
User Integration Testing (UIT)	£9,359
Implementation to Live	£17,692

The DCC costs have been provided for both parts combined. More information can be found in the DCC Impact Assessment response in Annex D.

### SECAS costs

The SECAS implementation costs to implement this modification is two days of effort for each part of the solution, amounting to approximately £1,200. The activities needed to be undertaken for each part are:

- Updating the SEC and releasing the new version to the industry.

### SEC Party costs

Working Group Consultation respondents said that they would all incur costs to a degree, either through changes to their business processes or technical implementation costs. Some respondents noted they required additional information before being able to provide an accurate picture of how large these costs would be. One respondent noted that the costs incurred to them would be low and another estimated the overall cost to them would outweigh the benefits this modification would deliver. The full responses can be found in Annex E.

## 6. Implementation approach

---

### Implementation approach

The Panel agreed a two-part implementation approach where:

- Part 1 will be implemented on **25 June 2020** (June 2020 SEC Release); and
- Part 2 will be implemented on **5 November 2020** (November 2020 SEC Release)

if a decision to approve is received on or before 7 February 2020.

The DCC's Impact Assessment identifies a six-month lead time to deliver the modification's full solution, meaning it would not be possible to include Part 2 in the June 2020 SEC Release. The DCC has confirmed it can deliver the changes for Part 1 of the solution in the June 2020 SEC Release. The November 2020 SEC Release is currently the next SEC Release where DUIS changes are anticipated, and so for efficiency it was agreed that Part 2 should be included alongside these. If other DUIS changes are approved for implementation at an earlier date, the Panel can request the Authority revise the date for Part 2 accordingly.

Part 1 of the Modification Proposal's solution will look to be implemented in the June 2020 SEC Release. This way, Part 1 of the solution with the solution's consolidation mechanism and reporting will be active, without requiring DUIS changes. After discussing the first Modification Report Consultation responses with Electricity Network Parties, so long as the email notifications being generated from SECMP0062 could be turned off whilst there are numerous incidents and that clear reporting is taking place through the SSI and the TOC, Part 1 got agreement from the Working Group to be implemented in the June 2020 SEC Release.

## 7. Discussions and development

---

### Will the mechanism in the proposed solution have unintended consequences in its consolidation process?

The Working Group considered unintended consequences that could arise. One potential impact noted was that the solution's mechanism could potentially filter out Alerts that Users want to keep a record of. It was noted that, under the initially proposed configurable parameters, a User would receive in excess of 50 copies of a particular Alert before throttling would occur and would still receive one in 10 of subsequent copies. However, members still felt there would be some Alerts for which they would want to receive all copies, regardless of the situation. The Working Group therefore created a list of Alerts they deemed it would be beneficial to be exempted from the mechanism. The content of this list of Alerts affected was determined as part of this modification's refinement and a question was asked in the Working Group Consultation asking for Alert Codes that respondents feel should not be subject to throttling.

The Working Group agreed that a new document, called the 'Traffic Management Mechanism Document', would be created, which would document the list of exempted Alert Codes plus the parameters used by the DCC. This document would sit outside the SEC, meaning it would not require a Modification Proposal to amend its contents. However, all changes to this must be agreed with the Panel (or a Sub-Committee nominated by it) before they take effect.

### How big is the impact of the proposed solution?

The Working Group considered the scope of the proposed solution. It was noted that the solution that was being designed only counters Alerts that are generated by Alert Storms from a single Device rather than multiple Devices sending out the same Alert. The DCC confirmed this was the case as each Device would be registered as an individual incident for the purposes of recording Alerts breaching the threshold to trigger the throttling mechanism.

The DCC provided the following analysis to model outcomes where its mechanism is in effect against the four Alert Codes with the greatest volume. The DCC modelled this by taking an actual count of each Alert type on a per Device level that was queried from the service audit trail for the 31 December 2019. This query returned a list of 380,861 devices generating a total of 43.3 million device alerts for that day. This day was chosen as it was one of the days with the highest number of Device Alerts. This may not be correct in all instances, especially where a large quantity of Devices are generating a small number of Alerts as this may not breach the Red Threshold for Alert Anomaly Detection.

The approach for each calculation is summarised below:

#### **1 in 10**

Where a Device generated more than 10 Device Alerts on the 31 December 2019 and generated more than 10 Device Alert of a specific alert type (e.g. 8F3E), then only 1 in 10 of that Device Alert is passed on.

#### **1 in 500**

Where a Device generated more than 10 Device Alerts on the 31 December 2019 and generated more than 10 Device Alert of a specific alert type (e.g. 8F3E), then only 1 in 500 of that Device Alert is passed on.

Total Alerts under different scenarios			
Alert	No consolidation	N=10	N=500
8F3E	37,176,005	3,767,340	133,752
8014	602,857	114,232	70,404
8015	604,485	114,190	70,236
8F12	2,525,257	277,464	32,452
<b>Sum</b>	<b>40,908,604</b>	<b>4,273,226</b>	<b>306,844</b>
<b>Reduction</b>	-	<b>89.5%</b>	<b>99.3%</b>

This analysis suggests if the mechanism designed is implemented, it should eliminate approximately 99.3% of individual Devices providing repeated Alerts through Alert Storms. It would mean, in this particular instance, the solution would reduce repeated Alert traffic in the DCC Systems considerably. However, where the problem is not limited to a single Device this will have a reduced effect.

Given the cost attached to the modification's solution to its limited scope, this focused the business case towards how much more capacity this can provide the DCC Systems compared to if the modification is not accepted and subsequently allowing the system to fail. Given this allowed greater efficiency of the current infrastructure rather than a more expensive expansion of the current DCC System capacity, the benefits for this modification were seen as worth the industry cost of the modification.

### Would the traffic management solution be better placed as firmware for Devices, rather than specifically to the DSP?

Members of the Working Group raised the question as to whether it would be more effective if the solution was implemented through firmware to Devices to prevent excessive numbers of Alerts being generated through Alert Storms, rather than as part of the Data Service Provider (DSP) system. The motivation behind this was that by addressing the problem at an individual Device level rather than through the DCC Systems, it could be used to properly address the source of the problem rather than its symptoms.

The DCC considered this in the first Working Group meeting and understood the concerns raised. In turn it provided the Working Group with data and information relating to the CSP that showed why it would be more desirable to implement the solution through the DSP rather than through firmware. Ideas were therefore discussed surrounding the viability of an alternative solution with the same filtering mechanism being utilised at a CSP level.

The DCC informed the Working Group the Modification Proposal is intended for the consolidation of Alerts received by the DSP. It had taken this into account for an alternative solution but claimed this would create a significant issue. This alternative solution would mean adjusting the parameters of every affected Device rather than changing the settings of the central systems, which would take significantly longer to administer the changes. The DCC noted this could leave a number of Devices during this time without communicating capabilities through DCC Systems.

The DCC is working with the CSPs to identify both Communications Hub and Device based solutions; however due to the nature of the changes needed, they are likely to take an extended time to be implemented and would likely also be dependent upon SECMP0062 having been implemented. The DCC has expressed that due to the impacts of Alert Storms currently being experienced, the DSP

solution should be used whilst a CSP solution is being explored. Information gained from this solution will also be used as part of any root cause analysis to better identify future changes addressing the root cause of the issue.

The Working Group stated that the proposed solution was the ideal solution choice to be progressed under this modification. Any alternative solutions for consideration that look at providing Alert filtration should be raised in a separate modification and that way would provide another layer of security alongside SECMP0062.

## **Will there be a means of notification for Users when Alerts are being controlled in the first stage of the implementation approach?**

As part of the solution's development, it was proposed that, in order to progress the modification faster and make sure the lead time was sufficient for delivering the solution, a two-stage implementation approach could be taken. The first stage would deliver all of the business requirements in Annex A with the exception of Requirement 2 around implementing a mechanism to notify Users when an Alert has been throttled. This would be delivered in the second stage with the relevant changes to DUIS being implemented at that point in time.

As part of this, the Working Group requested, during this first stage of the process, that a form of active notification be investigated given to Users as otherwise the only means of Users being able to identify Device/Alert Code combinations being controlled would be to manually check the SSI dashboard. The DCC informed the Working Group that it could provide an email notification when Incidents were created when a Device/Alert Code combination was being controlled. This received a mixed response from the Working Group, with some being in favour as this gave the desired notification, but others expressing concern that if this was an email for every Alert that this could cause administrative issues and create a backlog which would waste resources on the part of Users whose Devices generate large numbers of Alerts.

The Working Group elected to seek views from Parties as part of the Working Group Consultation to confirm which approach should be taken for notification. The Working Group Consultation returned an even split of respondents who saw benefit of being actively alerted in the case of incidents triggering the solution's mechanism and respondents who believed that this notification would cause administrative issues to them and negatively impact their business processes. The DCC, as the Proposer of the modification, took note of the consultation responses and altered the solution so that the User can choose whether to be notified by an email in the case of an incident triggering the mechanism or to not be notified by email, instead using the SSI dashboard to see when the mechanism is active.

One respondent to the subsequent Modification Report Consultation had a concern that a significant number of incidents could be registered per Device in the DCC Incident Management System. In turn, they believed this would increase both the DCC and User resource costs. The DCC believes that this concern will be covered by its "dead-banding" in the incident creation process. Under Alert Storm Protection only 1 in n (currently set to 500) Alerts will be delivered to the User. If the n limit is not reached within the configurable time period (currently set to 1440 minutes) then one Alert will be delivered to the User at this point. A new Incident will not be created unless the Alert count has been below the threshold for a continuous 1440 minute period.

The same respondent had concerns over the email system, asking whether building email functionality was the best choice of notification, considering that a large volume of email traffic would negatively impact both the DCC and Users. The DCC has stated that the email functionality would not

be built from scratch, instead re-using the existing functionality in the DSMS, making it cost-effective. It further believes the Impact Assessment covered the effects that would be had on the DCC Systems, the DSMS and email systems.

## Network Party concerns

Network Parties have cited a number of concerns with the proposed solution, including:

- They felt the solution in its current state would cause greater administrative burdens via email notification for every raised Incident than removing nuisance Alerts;
- The Alerts on the exemption list at the time; and
- The Modification Proposal deals more with the symptoms of the issue, rather than the root cause of why so many Alerts are being generated.

SECAS and the DCC arranged meetings to address the concerns raised by the Network Parties. After seeking additional feedback from the Electricity Network Parties who responded to the consultation, the DCC made amendments to the solution. These amendments included extending the deadband period so that fewer incidents would be created (when enabled). This change was chosen due to the need for sufficient reporting while acknowledging the earlier concerns that emailing for every incident could cause administrative issues.

## Who will manage the Exempted Alerts List and configurable parameters?

The DCC confirmed its support for the Panel to delegate responsibility to the Operations Group to oversee management of the reporting as well as the management of the Exempted Alert list and the wider solution mechanism's configurable parameters. The Working Group agreed with this but wanted the Security Sub-Committee (SSC) and the Technical Architecture and Business Architecture Sub-Committee (TABASC) to provide input to the Operations Group meetings where this is discussed.

## What is the longer-term plan for Traffic Management solutions?

The DCC has stated that for other issues raised outside the scope of the Modification Proposal, future modifications would be the best route to pursue these. Future SEC modifications could be raised to address these particular issues:

- Creating a new configuration for different Alerts with different thresholds;
- Creating User- (or User Role-) specific configurations to account for Users who use differing configuration on Device; and
- Implementing changes to Device testing processes to further prevent generation of nuisance alerts, something raised by Network Parties to investigate the root causes of Alert Storms.

The DCC has stated that these will require DCC Assessments to assess in more detail.

## 8. Conclusions

---

### Benefits and drawbacks

The Proposer and the Working Group have identified the following benefits and drawbacks in implementing this modification:

#### Benefits

- The main benefit of this modification is that it should prevent the overload of the DCC Systems as a result of an Alert Storm which would cause the DCC's DSP to fail and disrupt communications between Devices and Suppliers. If left unattended, the risk of Alert Storms causing this overload will continue to be an issue for the Service Users and the DCC where if the DSP does fail, this will incur both financial costs and time delays to the Service Users which could be avoided if this modification and its solution is enabled successfully. The DCC has quoted a rough order of magnitude cost from the DSP that stands at approximately £3 million to £3.5 million to cover the infrastructure demands that SECMP0062 could mitigate<sup>1</sup>.

The DCC provided a worked example of Alert Storm values carried out where 1 in 500 Alerts would be delivered to the User against the four Alert Codes entering the DCC Systems with the greatest volume. Under these conditions the example demonstrated a reduction of approximately 99.3% of the repeated Alerts generated under this scenario reducing a total of 40,908,604 Alerts to 306,844. The DCC has confirmed this is only based on a single day's worth of Alert traffic, and that this may not be correct in all instances, especially where a large quantity of Devices are generating a small number of Alerts.

#### Drawbacks

- In Working Group discussions, a member raised the issue that the changes to the SEC may require compulsory changes to the DUIS, which could be unpopular with the wider industry if introduced quickly. This added a complication to the implementation approach which needed consideration given the Working Group wanted to have this Alert Storm protection as soon as possible. The two-stage implementation approach was proposed so that the DUIS changes could be implemented later.
- Another drawback that was raised in the Working Group was the timeline of the modification. The earliest time that the modification could be effective from is June 2020, due to the necessary length of the Refinement Process and implementation period needed for SEC Parties to carry out the changes that the modification proposes. This earliest time of implementation was criticised due to the desirability of the modification's solution and that it should be released ideally as soon as possible to gain the most utility from the protection it will provide against Alert Storms.

---

<sup>1</sup> See minutes for OPSG\_27\_0312

## Proposer's rationale against the General SEC Objectives

### Objective (a)<sup>2</sup>

The Proposer believes that SECMP0062 will better facilitate General SEC Objective (a) due to it allowing the DCC to better carry out their obligations as outlined in the SEC and improves the operation of Smart Metering Systems to a greater degree by providing additional protection to the DCC's DSP.

### Working Group members' views

The Working Group agreed that this modification better facilitates General SEC Objective (a) for the reasons cited above.

### Consultation respondents' views

The Working Group Consultation respondents returned a mixed set of responses. Five of the eight respondents were in favour of approving the modification and three were against it. The three respondents not in favour were Networks Parties whose reasons for rejecting the modification were due to not addressing the root cause of why such large quantities of Alerts are being generated. They suggested that the solution should be targeted at preventing the Devices generating such large quantities of Alerts, rather than filtering the Alerts after they've been sent.

In the first Modification Report Consultation, two Large Suppliers and the Security Sub-Committee were supportive. Four Electricity Network Parties were not supportive and expressed concerns as to how the reporting would be managed and that they would suffer administrative issues through Part 1 of the solution. Clarifications were made to the reporting following this and SECAS agreed with DCC that the email notification could be turned off so that email notifications would not cause administrative issues for Users.

In the second Modification Report Consultation respondents again returned a mixed set of responses. Three of the seven respondents were in favour of approving the modification and four were against it. The three respondents in favour were Large Suppliers, who believed that the Modification Proposal, whilst not directly dealing with root causes to Alert Storms, provides a solution to a considerable burden on the DCC Systems and should alleviate needless traffic. The four respondents who voted to reject were Network Parties who raised concerns that their previous comments weren't sufficiently addressed concerning the email notifications and that it still left the root causes of Alert Storms unchanged. The DCC responded to the concerns raised by Network Parties by explaining that a CSP based solution that would deal with the root causes would take approximately 2-3 years to develop. In the meantime, it stated that this provided a solution to a present and urgent issue.

### Sub-Committee views

The SSC chairman was on the Working Group and attended one of the meetings when the business requirements were being formulated. The view provided on behalf of the SSC was that security Alerts should not be restricted. They stated a solution could be supported where a list of exempted security-

---

<sup>2</sup> Facilitate the efficient provision, installation, operation and interoperability of smart metering systems at energy consumers' premises within Great Britain

related Alerts that will not be subject to throttling or subject to a different level of throttling can be approved by the SSC and for SSC to receive regular reports.

The Operations Group agreed to have oversight of the reporting and manage any issues which might arise from the reporting. In addition, this group will have the responsibility to review and update the configuration parameters.

## **Panel's conclusions**

The Panel agreed this Modification Proposal is ready to proceed to a decision under Self-Governance.



## Appendix 2: Glossary

This table lists all the acronyms used in this document and the full term they are an abbreviation for.

Glossary	
Acronym	Full term
CSP	Communication Service Provider
DCC	Data and Communications Company
DECC	Department of Energy and Climate Change
DSMS	DCC Service Management System
DSP	Data Service Provider
DUIS	DCC User Interface Specification
ISFT	Invitation to Submit Final Tender
PIT	Pre-Integration testing
S1SP	SMETS 1 Service Provider
SEC	Smart Energy Code
SIT	System Integration Testing
SMETS	Smart Metering Equipment Technical Specification
SSC	Security Sub-Committee
SSI	Self Service Interface
SSMI	Self Service Management Interface
TABASC	Technical Architecture and Business Architecture Sub Committee
TOC	Technical Operations Centre
UIT	User Integration Testing



If you have any questions on this modification, please contact:

**Harry Jones**

020 7081 3345

[harry.jones@gemserv.com](mailto:harry.jones@gemserv.com)

**Smart Energy Code Administrator and Secretariat (SECAS)**

8 Fenchurch Place, London, EC3M 4AJ

020 7090 7755

[sec.change@gemserv.com](mailto:sec.change@gemserv.com)

This document is classified as **White** in accordance with the Panel Information Policy. Information can be shared with the public, and any members may publish the information, subject to copyright.

# SECMP0062 ‘Northbound Application Traffic Management - Alert Storm Protection’

## Annex A

### Business requirements – version 1.0

#### About this document

---

This document outlines the detailed business requirements for SECMP0062.

## Summary

---

The DCC and Service Users communicate through the use of DCC Systems for sending service requests and alerts for different registered Devices. Due to the DCC system having a finite capacity for how many requests and alerts it can handle, if this system becomes overloaded, it will affect the stability and performance of the system. This system is also vulnerable to Alert Storms, a state where individual Devices will encounter a scenario where they frequently generate the same Alert and send it through the DCC Systems. This adds needless traffic to the DCC Systems and, as a result, slows down the response time for other Alerts and Service Requests that have to use the same system as a means of communication. Alert Storms therefore need to be avoided as much as possible, or alternatively, traffic management needs to be in place to prevent repeated Alerts from a faulty device entering the system.

This solution will protect against the scenario in which a specific Alert is generated repeatedly and rapidly by individual Devices. However, it is noted that it will not, and is not intended to, protect the DCC Systems against a large quantity of Devices that generate a small number of alerts which enter the DCC Systems (e.g. due to a power outage over a large area).

## Business Requirements

---

**Requirement 1: The DCC will implement a mechanism that will block Alerts from entering the DSP Central System and being routed on to the User where the number received exceeds a given threshold.**

The DSP (Data Service Provider) System will monitor the number Alerts received from a Device. When the total number of Alerts received from an individual Device within a rolling time period T exceeds a threshold A, an incident is created for that Device.

While an incident is open, the DSP System will monitor the number of each specific Alert received from the Device. When the total number of copies of a specific Alert received from the Device within a rolling time period R exceeds a threshold B, the Device/Alert combination will be marked as overloaded and an additional incident is created for that specific Device/Alert.

As part of the Impact Assessment, DCC will specify the expected Service Level Agreements for DCC and DCC Users to respond to incidents.

When a Device/Alert combination is marked as overloaded, only 1 in N copies of the Alert will be passed to the User, with all other copies being blocked by the DSP System. The copies of the Alert that are allowed through will still be subject to the normal Target Response Times.

A Device/Alert combination will no longer be overloaded when the number of copies of that Alert received in a rolling time period R falls below threshold B. At this point, those Alerts will no longer be blocked. The number of blocked Alerts will still be counted in determining this threshold.

The values to be set upon implementation of SECMP0062 are:

- T = 30 minutes
- A = 50
- R = 5 minutes
- B = 10
- N = 10

The values of T, A, R, B and N will be configurable values in the DSP System that can be changed at any time. They will not be hard-wired into the System.

The parameters will be 'global' values that are applicable to all DCC Users. It will not be possible for different Users to set different values specific to them.

This process will be applied to all SMETS (Smart Metering Equipment Technical Specification) 2 Alerts. It will also be applied to any SMETS1 Alerts that have been mapped to an equivalent SMETS2 Alert.

As part of the Impact Assessment, DCC is asked to provide details of what will happen to blocked Alerts in terms of storage and discarding.

**Requirement 2: The relevant User will be notified when Alerts have been subject to throttling.**

Users will be notified that Alerts have been blocked through the non-mandatory metadata fields of those Alerts that are allowed through. Users will be required to update their systems if they wish to be able to receive this additional information.

It is expected that this requirement will be implemented through a new DCC User Interface Specification (DUIS) version.

The Working Group is considering the potential for a staggered implementation approach where Requirements 1, 3, 4, 5 and 6 are implemented as soon as possible while the DUIS changes for Requirement 2 are implemented in a later SEC Release. To inform the appropriate way forward, DCC is asked to provide an approach to be taken for alerting DCC Users in the interim period, to include the expected time period in which DCC Users will be notified of when the throttling of Alerts begin if the mechanism is in operation, as part of its Impact Assessment response.

Additionally, as part of the Impact Assessment response, DCC is asked to provide a full analysis of a solution with email notification during the first stage during this staggered approach, and one without.

**Requirement 3: There will be a configurable list of exempted Alerts that will not be subject to throttling or subject to a different level of throttling.**

The DSP System will contain a configurable list of Alerts that will not be subject to this mechanism or will be subject to this mechanism but with different values for the parameters R, B and/or N. The number of copies of these Alerts received will still be used to determine a breach of the threshold A. This list should be capable of being updated at any time and will not be hard-wired into the System.

Any variations set using this Requirement 3 will be 'global' variations that are applicable to all DCC Users. It will not be possible for different Users to set different values specific to them.

**Requirement 4: DCC will not amend the list of exempted Alerts without approval from the Panel or a delegated Panel Committee.**

DCC will not amend the list of exempted Alerts without obtaining approval from the Panel (the Panel may delegate this responsibility to a Panel Committee determined by the Panel).

**Requirement 5: DCC will not change the values of the parameters without approval from the Panel or a delegated Panel Committee, except in well-defined exceptional circumstances.**

DCC may change parameter values without consent in clearly defined circumstances which will be agreed as part of the solution definition in response to an urgent need to amend one or more parameters. It will then retrospectively report any changes of these to the Panel.

Otherwise, DCC will not change the values of parameters without obtaining approval from the Panel (the Panel may delegate this responsibility to a Panel Committee determined by the Panel).

As part of the Impact Assessment, the DCC is asked to provide examples of where it would need to urgently respond to events that warrant a rapid change of the parameter values. The Working Group will use this to determine if any such circumstances should be defined.

**Requirement 6: DCC will provide reporting on the use of throttling of Alerts.**

DCC will report on how often the mechanism introduced under SECMP0062 is used. This will cover the number of incidents raised and the number of Device/Alert combinations that are classed as overloaded within a given reporting period. As part of this report, DCC will provide a full updated list of Alert parameter values and any exempted Alerts or Alerts with different parameters, so DCC Users know which restrictions are placed against each types of Alert.

This document is classified as **White** in accordance with the Panel Information Policy. Information can be shared with the public, and any members may publish the information, subject to copyright.

# SECMP0062 'Northbound Application Traffic Management - Alert Storm Protection' version

## Annex C

### Traffic Management Mechanism Document version 2.0

#### Purpose of this Document

This document has been prepared in accordance with SEC Appendix AB 'Service Request Processing Document' Section 17.10 where the Alert Management Mechanism implemented by the DCC has its mechanism parameters and exempted Alert Codes clearly defined.

#### Parameter Values

There are eleven parameters that control the Alert Management Mechanism. Each parameter can be configured.

All the parameters are used in accordance with SEC Appendix AB Sections 17.8 and 17.9. These are global settings and will apply equally to all Devices and Alerts, unless that Alert Code is on the Exempted Alert Code list below.

Parameter	Description	Value
T	Rolling Window (Time Period) for Alert Anomaly Detection	1440 minutes
M	Amber Threshold for Alert Anomaly Detection	15
A	Red Threshold for Alert Anomaly Detection	20

These are the Existing Alert counting parameters. With these settings, a Device generating more than 20 Alerts in 1440 minutes (1 day) will invoke Alert Code specific counting.

Parameter	Description	Value
R	Alert Code Specific Rolling Window (Time Period)	1440 minutes
B	Alert Code Specific Threshold	20

These parameters are Alert Code specific. A Device generating more than 20 Alerts with a specific Alert Code in 1440 minutes (1 day) will invoke Alert Storm Protection for that Alert Code on that Device.

Parameter	Description	Value
N	Alert Storm Protection Discarded Alert Limit	500
D	Alert Storm Protection Maximum Time Limit	1440 minutes
P	Alert Storm Protection Incident Deadband Period	1440 minutes

With the above parameters and configuration, under Alert Storm Protection only 1 in 500 Alerts will be delivered to the User. If the 500 limit is not reached within the 1440 minutes (24 hour) time period then one Alert will be delivered to the User at this point. A new Incident will not be created unless the Alert count has been below the threshold for a continuous 24 hour period.

Parameter	Description	Value
MIC	Amber Threshold Incident Creation	Off
AIC	Red Threshold Incident Creation	Off
PIC	Alert Storm Protection Incident Creation	Off

The above parameters control incident creation and can be turned either on or off.

## Alert Storm Protection Exclusion List

The following Alert Codes are to be exempt from the global settings applied to all Alerts by the Alert Management Mechanism.

Exempted Alert Codes and Description
0x8F78 Unauthorised Physical Access - Other
0x8F77 Unauthorised Physical Access - Second Terminal Cover Removed
0x8F76 Unauthorised Physical Access - Terminal Cover Removed

## Exempted Alert Codes and Description

0x8F75 Unauthorised Physical Access – Strong Magnetic field

0x8F74 Unauthorised Physical Access - Meter Cover Removed

0x8F73 Unauthorised Physical Access - Battery Cover Removed

0x8F3F Unauthorised Physical Access - Tamper Detect

0x8F1F Low Battery Capacity

0x8F1D GSME Power Supply Loss

0x81C0 Supply Disconnect Failure

AD1 Power Outage


0x8F36 Power Restore

0x8F35 Power Restore

# **SEC Modification Proposal, SECMP0062**

## **Alert Storm Protection**

### **DCC Full Impact Assessment**



<b>Version:</b>	<b>1.43</b>
<b>Date:</b>	<b>3<sup>rd</sup> July 2019</b>
<b>Author:</b>	<b>DCC</b>
<b>Classification:</b>	<b>DCC Public</b>

## Contents

1	Introduction .....	3
2	Impact on DCC's Systems, Processes and People .....	5
3	Impact on the SEC.....	17
4	Testing Considerations.....	18
5	Implementation Timescales and Releases.....	19
6	DCC Costs and Charges .....	20
7	RAID.....	22
8	Related Documents.....	23

# 1 Introduction

## 1.1 Document Purpose

The purpose of this DCC Full Impact Assessment (FIA) is to provide the relevant Working Group with the information requested in accordance with SEC Section D6.9 and D6.10.

## 1.2 Previous information provided by DCC

The DCC Preliminary Assessment was provided on 31/01/2019.

## 1.3 DCC Contact Details

Please raise any queries regarding this DCC Impact Assessment using the contact details provided below.

<b>Name</b>	DCC - SEC Modification queries
<b>Contact email</b>	<a href="mailto:mods@smartdcc.co.uk">mods@smartdcc.co.uk</a>

## 1.4 Modification Description

This modification is to enable the implementation of a traffic management solution to protect the DCC (Data Communications Company) system and Service Users against alert storms originating from a single device.

Alert storms occur when devices repeatedly send alerts to DCC Systems and Service Users. Although these devices have gone through rigorous test assurance processes, it is inevitable that not every possible combination and scenario will have been accounted for. This means that many devices pose a risk of entering a state whereby they repeatedly and rapidly generate the same device alert, adding unnecessary traffic to the Communication Service Provider (CSP) Gateway, which in turn results in increased traffic between the DCC Systems and Service Users. Currently there is little protection against alert storms, meaning that multiple alerts are entering the gateway, rather than being filtered out, even after recognising they originate from the same single device.

## 1.5 Requirements

The requirements for this modification have been developed by the Working Group during the Refinement phase and are documented in the Business Requirements v1.0 document [Ref 1] and summarised below. The impact on DCC has been assessed against these Business Requirements.

BR #	Summary	Relevant Sections of this document
1	<i>The DCC will implement a mechanism that blocks Alerts from entering the DSP System where the number received exceeds a given threshold.</i>	Section 2
2	<i>The relevant User will be notified when Alerts have been subject to throttling.</i>	Section 2.1 Section 2.1.3 Section 2.1.4 Section 2.1.9
3	<i>There will be a list of exempted Alerts that will not be subject to throttling or subject to a different level of throttling.</i>	Section 2.1.2
4	<i>DCC will not amend the list of exempted Alerts without approval from the Panel or a delegated Panel Committee.</i>	Section 2.1.11
5	<i>DCC will not change the values of parameters without approval from the Panel or a delegated Panel Committee, except in well defined exceptional circumstances.</i>	Section 2.1.11
6	<i>DCC will provide reporting on the use of throttling of Alerts</i>	Section 2.1.12

## 2 Impact on DCC's Systems, Processes and People

This section describes the impact of SECMP0062 on DCC's Services and Interfaces that impact Users and/or Parties.

### 2.1 Description of Solution

In the Preliminary Impact Assessment [Ref 2], a two stage implementation approach was proposed to enable early implementation of the core functionality with the DUIS Alert specification changes following later.

Stage 1 of the solution will incorporate:

A Core Alert Storm Protection mechanism, that will provide a means of counting and discarding excess alerts. Generate anomaly events and initiate incidents. Create event and discarded alert records for reporting and monitoring.

To provide visibility of system activity, a dashboard will be provided in the SSI (Self Service Interface) and SSMI (Self Service Management Interface). When the protection mechanism is activated for a specific device/alert code combination an anomaly event will be recorded and will result in the creation of a DSMS (DCC Service Management System) Incident.

Specific alert codes may be configured to be excluded from the protection mechanism. This will be a global configuration.

Protection mechanism events and discarded alerts will be recorded, and used to form the basis of defined reports.

No changes to User systems will be required for this stage.

Stage 2 of the solution will incorporate:

Changes to the Alert Structure specification within the DUIS (DCC User Interface Specification). These changes will provide real time notification of alert throttling and enable Users to leverage this if required. To achieve this Users would need to implement the update to DUIS.

The details of the Stage 2 functionality are in section 2.1.9.

#### 2.1.1 Core Alert Storm Protection Processing

The DSP system already includes an anomaly detection solution for northbound alerts from a single device. This follows a pattern where alerts are counted over a configured time period (for example 30 minutes). If the total number in that rolling time period exceeds a configured threshold (defined by amber and red levels) then an anomaly is reported via the security log and a DSMS (DCC Service Management System) incident is created.

However the existing anomaly process does not protect the service by either quarantining or limiting alert volumes.

In order to protect the system from high volumes of northbound alerts, the existing anomaly detection service will be extended as follows.

1. When the number of Alerts from a given device within time window [T] exceeds the threshold value [A] the system will begin to count the number of Alerts from that device on a per Alert Code basis.
2. If any individual Alert Code count within time window [R] exceeds the configured threshold value [B] then that Originating Device/Alert Code<sup>1</sup> combination will be marked as being 'overloaded'.
3. If an Alert Code is marked as 'overloaded' for a device, then only one in every [N] such Alerts will be processed. All other Alerts with that same Alert Code from the same device will be discarded.
4. Once the rate of Alerts for the device falls below threshold [A] then the specific Alert Code counting will stop and any overloaded Alert Codes will be cleared. Alert processing will then return to normal.

The initial proposed configuration parameters are:

Parameter	Summary	Value
A	Device Alerts Threshold	50
T	Device Alerts Time Window	30 minutes
B	Individual Alert Threshold	10
R	Individual Alert Time Window	5 minutes
N	Number of dropped alerts between forwarded alerts	10

The parameters above are global settings and will apply equally to all devices and alerts., unless that alert code is on the excluded list.

When a Device/Alert Code is marked as overloaded and the protection mechanism is active, the Alerts to be dropped will be logged and counted but then discarded from the system.

---

<sup>1</sup> Uniqueness of counts will be by Originating Device AND Alert Code




Table 1 Normal and Overloaded message flows

The diagram below shows the existing sub-components impacted due to this change and the new sub-components that are required to be built along with the key steps involved.




Figure 1: Northbound Alert Protection - Steps involved

### 2.1.2 Configuration Settings

The Alert Code Threshold settings will be managed using application configuration parameters, similar to the way the generic northbound ADT settings are managed currently. These configuration parameters will be global, i.e. apply to all Users, Devices, and Alert Codes (with the exception of exempted Alert Codes).

The list of Alert Codes, which shall be exempted from the Alert Storm Protection processing, will also be managed using application configuration parameters. DCC assumes that an agreed list of exempt Alert Codes will be provided by the SEC Panel or a delegated committee such as TABASC.

### 2.1.3 Status Dashboard

A new Self Service Interface (SSI) dashboard for Service Users will be built using the existing dashboard design principles. This dashboard will provide the Alert Storm Protection data to the Service Users, which will include the following details.

- Devices that exceed the threshold;
- Alert Codes that are subjected to Alert Storm Protection processing for each Device;
- Number of Alerts received for each Alert Code per device;
- Number of Alerts discarded for each Alert Code per device.

These would be 'live' views, and with an ability to view and download historic data. Users will only be able to see details of devices for which they have a defined Role.

### 2.1.4 DSMS Incident Management Strategy

Incidents may be created by the Device Level threshold and the Alert Code threshold being breached. A notification of an incident may also be sent by email to a User. However Alert Storm Protection may initiate rapidly and potentially frequently if a device is generating alerts close to threshold values.

To avoid large number of incidents being created a revision to the anomaly events handling mechanism will limit the number by introducing a deadband duration between the events as shown in the diagram below.




Figure 2 Incident Management and Deadband duration

The device threshold anomaly event will be cleared only when the number of alerts falls below the threshold and stays below that threshold for a configurable deadband period.

If the rate drops below the threshold and then rises above the threshold again within the deadband period then a new anomaly event will not be created, instead the rise will be linked to the existing anomaly event. The previous deadband period will be cancelled and will be restarted once the rate falls below the threshold again. This mechanism allows longer time windows between events, resulting in a reduced number of DSMS incidents being created.

Additionally, creation of the following Traffic Management incidents will be configurable:

- DSMS incident created to notify the generic ADT threshold breach;
- DSMS incident created to notify the Alert Code specific threshold breach.

When an incident is created it will be assigned to the Target recipient of the Alert. If the alert is from a PPMID then the DSP will assign the incident to the Lead Supplier.

Email notification of incident creation can be enable/disable on a per Service User basis – this will be a global setting for that User and applies to all incidents not just those for Alert Storms.

## 2.1.5 Feature Switches

This CR will be built behind multiple Feature Switches:

- A Feature Switch to manage the introduction of Alert Storm Protection;
- A Feature Switch to control whether the Device alerts are actually discarded;
- A Feature Switch to control whether the Discarded Alert Log is delivered to DCC.
- A Feature Switch to enable the DUIS Alert Format change.

Feature switches provide flexibility by allowing new features and functionality to be included in a release, tested, and then disabled until required. This potentially allows environment usage to be optimised.

## 2.1.6 Affected Components

### Data Communication

The Data Communication component will need to introduce the following new functions:

- A mechanism to determine when to start/stop tracking the number of alerts on a per Alert Code basis at a device level and the associated housekeeping functions;
- Any message that is allowed to be passed on to Request Management (and subsequently to Anomaly Detection) while an alert is “overloaded” will include the number of alerts that are discarded at the CSP Gateway;
- The discarded alerts will be recorded in a “Discarded Alert” log at the CSP Gateway. This log will be transferred to the DCC via the Enterprise Systems Interface every 15 minutes in a similar fashion to the Service Audit Trail. (Noting that if no data exists for a 15 minute period then no log file will exist and no data will be transferred).

### Anomaly Detection

Anomaly Detection will introduce a mechanism used by Data Communication to notify the number of alerts that are blocked at the CSP Gateway. This is required to perform a correct calculation of the breach of ADT levels.

### Data Management / Data Model

Data Management will require changes to support the new anomaly detection level configuration for tracking on a per Alert Code basis.

Data Model changes are required to support the new alert tracking mechanism.

### Request Management

Request Management will need to introduce new alarm identifiers to differentiate the Traffic Management incidents that are raised because of overloaded alerts. The creation of these incidents will be made configurable.

Request Management will receive additional information about the discarded alerts from Data Communication when a Device Alert is passed through to Request Management for onward delivery to the User. Request Management will record this additional information in a Traffic Management log. This log will contain the details that will be displayed in the SSI dashboard. In situations where the alerts are targeted at the ACB (for example alerts from PPMIDs) then the corresponding Service User Id shall be included in the logs. The Traffic Management log will be transferred to the Reporting Database component.

## Reporting Database

The Reporting Database will process the Traffic Management log and create a set of aggregated data at 15-minute intervals, which will be used by SSI/SSMI.

## SSI/SSMI

The SSI (Self Service Interface) will need a new dashboard to present the details of blocked Alerts and the associated Device to the Service Users. This data comes from the aggregated Traffic Management Log data held in the Reporting Database.

The same dashboard will be made available via SSMI for use by DCC and DSP.

## Incident Client

The existing interface for creating incidents will not require any changes.

## DCC Service Management System

A change will be needed to support a new incident type(s) to notify the overloaded alerts. This requires a new Remedy Incident Template(s) and configuration for the new DSP alarm identifier(s).

In addition, the assumption is that the DCC requires all alert monitoring incidents to be automatically assigned to the related Service User. This will be achieved by new auto-triage workflow.

Once the rate of alerts for the device falls below the red threshold level then the specific alert code counting will stop and any overloaded alert codes will be cleared. However, any related open incidents will need to be resolved by the Service User or DCC in accordance with the DCC incident handling procedures.

The following activities will be required for DSMS:

- Update of the DCC SMS Design documents to include a new incident type;
- Co-ordinating the production of the Remedy Incident Template with DSP and DCC Operations;
- Configuration of the data load template and linkage to DSP alarm identifier on all Remedy environments;
- PIT Testing;
- Support for post-PIT Testing for all environments.

There are a number of BAU support activities required:

- Production deployment of data load template configuration and linkage to DSP alarm identifier;
- Receive knowledge transfer for the solution changes;
- Release management.

## Operational Monitoring

The changes made under this CR will need to be integrated with the DSP's operational monitoring facilities.

Events created for alert code specific anomaly thresholds being breached or cleared will be tracked and reported in the DSP operational monitoring tools.

Events or alarms created by the DSP operational monitoring tools will be available for distribution to the DCC. It is expected that any operational integration to DCC systems will be a separate improvement item to be elaborated and implemented under a separate Change Request.

### **2.1.7 Non Functional Impacts**

#### **Impact on Performance**

DCC does not expect that there will be a material impact on system performance as a result of this modification. This will be validated by the use of some specific regression tests during the implementation phase.

#### **Impact on Resilience**

There is no impact on the underlying resilience of the DSP solution.

#### **Impact on Disaster Recovery**

There is no change to the Disaster Recovery solution or BCDR procedures.

#### **Impact on Security**

This change includes the implementation of a traffic management solution in the northbound highway. There is no impact on the Protective Monitoring because there is no new infrastructure.

Once the traffic management solution is designed there may be a need to include it within scope of a future penetration test to ensure it is configured correctly.

Security Assurance will be provided to:

- Support to the PIT Team during implementation
- Review of design document where there is a potential security consideration
- Review of changes to the security audit trail logging
- Review of test artefacts and outcomes where there is a potential security consideration
- Attendance at meetings where required by the PIT Team

### **2.1.8 Impact on processing, storage and/or transmission of the DCC Data**

No material impact has been identified on the processing, storage and transmission of DCC Data from the proposals within this Change.

However DCC is already seeing volumes of alerts in excess of forecast values. If this Change were not to be implemented then there would be an impact on the DCC systems.

### **2.1.9 Impact on Interfaces**

For Stage 2 changes will be made to the Device Alert Structure and the DCC Alert Structure as defined in DUIS.

## DeviceAlertMessage Format

The DeviceAlertMessage format is applicable to SMETS2 or later Device Alerts. This message combines the GBCS Payload received from the Device with the Alert Code extracted from the GBCS Payload. If an Alert Code is subject to throttling, two new optional data elements are included for the sequence number of the passed through alert and the count of discarded alerts:

- ThrottledAlertSequenceID
- ThrottledAlertDiscardedCount




Figure 3 - DeviceAlertMessage Structure

Data Item	Description / Valid Set	Type	Mandatory	Default	Units	Sensitivity
AlertCode	Code indicating the alert or reason for the alert to be generated GBCS includes '0x' at the start of such codes. This definition uses a hexBinary representation for valid values. Valid set: See GBCS for base list and apply hexBinary representation of these GBCS defined values	xs:hexBinary	Yes	None	N/A	Non-Sensitive
ThrottledAlertSequenceID	An optional data item that identifies that this Alert Code is currently subject to throttling by the DCC Data Systems. If this attribute is included in the Alert then it indicates the sequence number for this Alert message since Alert throttling began.	xs:unsignedShort	No	None	N/A	Non-Sensitive
ThrottledAlertDiscardedCount	An optional data item used to indicate the number of Alerts that have been discarded by DCC Data Systems since the last Alert was forwarded to the Service User.	xs:unsignedShort	No	None	N/A	Non-Sensitive
GBCSPayload	See GB Companion Specification for Details for message construction. For Critical Device Alerts: Grouping Header    Alert Payload    0x40    SMD Signature For Non-Critical Device Alerts: MAC Header    Grouping Header    Alert Payload    0x00    SMD-KRP MAC	xs:base64Binary	Yes	None	N/A	N/A

Figure 4 - DeviceAlertMessage Format

## DCCAlertMessage Format

The DCCAlertMessage format is applicable to DCC Alerts generated by the DCC Data Systems.




Figure 5 - DCCAlertMessage Structure

There are circumstances where the Device Alert may have to be delivered to the User as a DCC Alert (e.g. Alerts from a PPMID). Two new attributes will need to be added to the definition of the DCC Alert in a similar fashion to the DeviceAlertMessage structure.

Data Item	Description / Valid Set	Type	Mandatory	Default	Units	Sensitivity
DCCAlertCode	Code indicating the Alert or reason for the Alert to be generated by DCC Valid set: See Table 49	Restriction of xs:string (Enumeration)	Yes	None	N/A	Non-Sensitive

Data Item	Description / Valid Set	Type	Mandatory	Default	Units	Sensitivity
DCCAlert	This is body specific content dependent on the DCCAlertCode being sent. See section 13 and Annex 16 for body specific format.	Sr:DCCAlert See section 13 and Annex 16	Yes	None	N/A	N/A
ThrottledAlertSequenceID	An optional data item that identifies that this Alert Code is currently subject to throttling by the DCC Data Systems. If this attribute is included in the Alert then it indicates the sequence number for this Alert message since Alert throttling began.	xs:unsignedShort	No	None	N/A	Non-Sensitive
ThrottledAlertDiscardedCount	An optional data item used to indicate the number of Alerts that have been discarded by DCC Data Systems since the last Alert was forwarded to the Service User.	xs:unsignedShort	No	None	N/A	Non-Sensitive

Figure 6 - DCC Alert Message Format

## 2.1.10 Impact on Infrastructure

No impact identified.

## 2.1.11 Impact on Business Processes

### Amendments to the list of exempted Alerts

DCC will develop appropriate Business Processes in support of Business Requirement 4, to ensure that changes to the list of exempted Alerts includes explicit approvals from the delegated SEC Panel committee.

### Amendments to the Alert Storm Protection configuration parameters

DCC will develop appropriate Business Process in support of Business Requirement 5, to ensure that changes to the Alert Storm Protection configuration parameters includes explicit approval from the delegated SEC Panel committee.

## 2.1.12 Impact on Reporting

To meet Business Requirement 6, DCC will report on how often the mechanism introduced under SECMP0062 is used. This will cover the number of incidents raised and the number of Device/Alert combinations that are classed as overloaded within a given reporting period.

In addition, the SSI dashboard will enable Service Users to view current Device and Alert code combinations that are currently being controlled and the associated numbers of forwarded and dropped alerts. It will also provide a means to download a historic report.

### **3 Impact on the SEC**

No changes to the GBCS are required.

A change to DUIS is required – the details are included in Section 2.1.9.

Detailed changes to the SEC will be a deliverable at the Design Stage, and will be implemented by SECAS.

## 4 Testing Considerations

This section outlines the testing required to complete the Design, Build and Test phases for this SEC Modification.

### 4.1 Pre-integration Testing

During Pre-Integration Testing (PIT), each Service Provider tests its own solution to agreed standards in isolation of other Service Providers. Specifically, the development team will carry out unit testing and the build will be subject to continuous build and automated testing to identify build issues at the earliest opportunity.

PIT will operate as a single phase of activity with a single drop. It will consist of a defined subset of system tests being observed by DCC.

### 4.2 Systems Integration Testing

Systems Integration Testing (SIT) is the testing of the DCC Total System, which brings together the components, e.g., DSP and CSP Systems, to allow testing of the end-to-end solution by DCC. SIT is carried out for every DCC System release and incorporates the test and integration of multiple changes. The SEC Modification and associated system changes will need to be demonstrated and tested as part of the integration test phases.

### 4.3 User Integration Testing

User Integration Testing (UIT) is referred to as User Testing in the SEC. User Testing of Modification Proposals is provided using the Modification Implementation Testing Service. It enables Users to run specific tests to support their implementation of a change.

## 5 Implementation Timescales and Releases

### 5.1 Change Lead Times

From the date of approval, (in accordance with Section D9 of the SEC), in order to implement the changes proposed DCC requires a lead time of **6 months**.

For Stage 1 DCC propose the following implementation plan:

**Table: November 2019 Release Timescales**

Phase	Start	End
SECAS and DCC confirmation of required November 2019 scope	March 2019	
Design, Build, and PIT Test	April 2019	Mid-July 2019
SIT Phase	July 2019	September 2019
UIT Phase	October 2019	October 2019
Transition to Operations and Go Live	October 2019	November 2019

For Stage 2 DCC propose the following implementation plan:

**Table: June 2020 Release Timescales**

Phase	Start	End
SECAS and DCC confirmation of required June 2020 scope	July 2019	
Design, Build, and PIT Test	August 2019	September 2020
SIT Phase	January 2020	April 2020
UIT Phase	May 2020	May 2020
Transition to Operations and Go Live	May 2020	June 2020

## 6 DCC Costs and Charges

### 6.1 Cost Impact

#### 6.1.1 Implementation Costs

The table below details the cost of delivering the changes and Services required to implement both Stage 1 and Stage 2 of this Modification Proposal.

Implementation costs							
Phase:	Design	Build	Pre-Integration Testing	System Integration Testing	User Testing	Implementation to Live	Total
<b>SECMP0062</b>		£964,346		£96,995	£9,359	£17,692	<b>£1,088,392</b>
Implementation costs – supplementary information							
<b>Implementation cost assumptions</b>	<p>A. Costs are exclusive of VAT and any applicable finance charges</p> <p>B. Majority of the costs above represent labour costs.</p> <p>C. Costs provided for Design, Build and Pre-Integration Testing are quotes provided by the Service Providers and assuming there is no scope change can be considered the final costs. DCC have reviewed and challenged the costs from the Service Providers to ensure this reflects best price to date.</p> <p>D. Costs will be refined during future assessments.</p>						
<b>Explanation of Implementation Phases</b>	<p>DCC's implementation costs are provided by implementation phases. The following describes the purpose of each phase:</p> <ul style="list-style-type: none"> <li>• <i>Design: The production of detailed System and Service design to deliver all new requirements.</i></li> <li>• <i>Build: The development of the designed Systems and Services to create a solution (e.g. code, systems, or products) that can be tested and implemented.</i></li> <li>• <i>Pre-integration Testing: Each Service Provider tests its own solution to agreed standards in isolation of other Service Providers. This is assured by DCC.</i></li> <li>• <i>System Integration Testing: All Service Providers' PIT-complete solutions are brought together and tested as an integrated solution, ensuring all Service Provider solutions align and operate as an end to end solution.</i></li> <li>• <i>User Integration Testing: Users are provided with an opportunity to run a range of pre-specified tests in relation to the relevant change.</i></li> </ul>						

- *Implementation to Live Costs: The solution is implemented into production environments and ready for use by Users as part of a live service. This service is subject to implementation costs.*

## 6.2 Impact on Charges

This section describes the potential impact on Charges levied by DCC in accordance with the SEC.

DCC notes that SECMP0062 does not propose any changes to the charging arrangements set out in SEC Section K. DCC has made the assumption that, in the absence of an agreed alternative arrangement by the Working Group, the costs associated with the implementation of SECMP0062 will be allocated to DCC's fixed cost based and passed through to Parties via Fixed Charges.

Subject to the commercial arrangements put in place to support the relevant Release, DCC expects the increase in Charges associated with the implementation of SECMP0062 to commence in the month following the modification's implementation.

## 7 RAID

### 7.1 Risks

Ref.	Risk Description	Risk Impact
R-001	None identified at this stage	n/a

### 7.2 Assumptions

Ref.	Description	Impact
A-001	Reports to be published for Business Requirement 6 will be made available via DCC Sharepoint	Low
A-002	The solution presented here includes the raising of DSMS Incidents. It is assumed that there is no requirement for the automatic closing of incidents after the related device falls below the device threshold.	Low
A-003	For northbound responses, the DSP system already includes a simple anomaly detection service that rejects/discards any Response for which the DSP does not have an outstanding corresponding Request. Assuming that a southbound traffic management solution will be put in place for Requests, there is no need for any extra northbound traffic management for Responses since any overload of valid Responses will be prevented by the traffic management on Requests and any overload of invalid Responses will be prevented by the anomaly detection service.	Low

### 7.3 Dependencies

Ref.	Description	Impact
D-001	SEC Panel or delegated Sub Committee to provide an agreed list of exempt Alert Codes (Section 2.1.2)	Medium

## 8 Related Documents

Ref:	Title
1	SECMP0062 Northbound Application Traffic Management – Alert Storm Protection Business Requirements – version 1.0
2	SECMP0062 – DCC Preliminary Impact Assessment v1.1
3	SECMP0062 Working Group Consultation Responses

This document is classified as **White** in accordance with the Panel Information Policy. Information can be shared with the public, and any members may publish the information, subject to copyright.

# **SECMP0062 ‘Northbound Application Traffic Management – Alert Storm Protection’ Annex E Working Group Consultation responses**

## **About this document**

---

This document contains the full non confidential collated responses received to the SECMP0062 Working Group Consultation.

## Question 1: Do you agree with the solution put forward?

Question 1			
Respondent	Category	Response	Rationale
Bryt Energy	Small Supplier	Yes	<p>While we agree in principle that the solution will meet the objectives of preventing alert storm capacity issues within the DCC and SEC User Systems, we are concerned two key steps need to be taken in parallel to support interim:</p> <ul style="list-style-type: none"> <li>The change in alert management architecture and alert storms was discussed in detail in initial DCC design workshops and discounted on the basis that DCC and DSP should not be responsible for alert management and pass all traffic to the SEC User. In this instance several actions need to be agreed before this MOD is passed: <ul style="list-style-type: none"> <li>TABASC agreement that the solution architecture and principles for DCC are changed under alert management;</li> <li>Root cause analysis on the current devices causing anomalous alert volumes, identifying alert type, identifying if the alert type is a valid GBCS alert device type, device firmware, SEC User; (Additional data should be time date postal code should be used to enrich the analysis)</li> <li>Identification of alert storms on the proposed alerts not to be subject to “Throttling”, in which would circumvent the proposed solution;</li> <li>SSC should be notified of the volume of anomalous alerts &amp; types; i.e. at present we do not know if they are security related and pose a genuine security risk to a device or firmware</li> </ul> </li> <li>DCC and SEC Users under the SEC have an obligation to investigate into anomalous alert &amp; alert volumes as per their internal ISMS Policies;</li> </ul>

Managed by

Question 1			
Respondent	Category	Response	Rationale
			<ul style="list-style-type: none"> <li>○ If this issue is related to a manufacture, device, particular firmware or particular alert, these parties along with SEC User should be tasked with resolving the issue at their cost;</li> <li>● DCC should undertake this root cause analysis and present into SEC Operations Working Group and task SEC Users to identify if the devices they currently supply and are responsible which are producing alerts that are anomalous a root cause based on:               <ul style="list-style-type: none"> <li>○ Genuine root cause reason; i.e. Large DNO outage in a geographical postal code;</li> <li>○ Anomalous root cause in device; i.e. Firmware Defects, Incorrect Device Configuration, Device Defects, Security Defects/Incidents</li> <li>○ Identify SEC Users not actively managing anomalous alerts;</li> <li>○ Core defect within GBCS or associated technical specifications;</li> <li>○ SEC Users to report back with analysis and next course of actions;</li> <li>○ Framework for interim analysis, reporting and monitoring agreed to be conducted on a regular basis until the DCC solution is fully implemented;</li> </ul> </li> </ul> <p>Proactive root cause analysis needs to be undertaken urgently for the following reasons:</p> <ul style="list-style-type: none"> <li>● If the current anomalous alert volume increases exponentially in line with current installations this could cause outages to the DCC and severely impact SEC Users</li> <li>● SEC Users could through CoS Gain be in receipt of unanticipated volumes of anomalous alerts that their architecture and solutions may not be able to cope with;</li> </ul>

Question 1			
Respondent	Category	Response	Rationale
			With this said, we would still recommend the throttling solution to minimise any future incidents, however recommend that anomalous alert management be tabled as an item in the Operation Working Group on a monthly basis to identify trends.
<b>EDF Energy</b>	Large Supplier	Yes	<p>We agree that the proposed solution appears to be reasonable, and would reduce the number of alerts that are unnecessarily processed through the DCC systems and consume processing resources unnecessarily.</p> <p>A clear definition of what constitutes a duplicate or excess alert will need to be clarified in order to develop the technical solution. It may be necessary to differentiate between alerts that are sent repeatedly as a result of an ongoing issue/situation/state in regards to the device sending the alert, as compared to repeat alerts that are occurring because the same situation/issue is being created repeatedly. In the latter case filtering the alerts may serve to hide the true nature of the problem.</p>
<b>Western Power Distribution</b>	Networks Party	No	We believe that the solution will help protect the DSP and User systems against only some Alert Storms and unnecessary volumes of traffic.
<b>SSEN</b>	Networks Party	No	This should assist in providing a throttle on the amount of device alerts we are currently receiving and alleviate pressure on our adapter based on current volumes. However, this will not solve the issue for all alerts that should be suppressed or assist in a sustainable throttle notification mechanism.
<b>E.ON</b>	Large Supplier	Yes	E.ON understands Alert Storms are one of the biggest issues faced by the DCC and recognises the DCC needs to take direct action to protect their systems and ensure availability of service. E.ON is supportive, in principle, for the need to implement changes.
<b>Npower</b>	Large Supplier	Yes	Will prevent DCC from falling over due to alert storms

Question 1			
Respondent	Category	Response	Rationale
Smartest Energy	Small Supplier	Yes	<p>As a small supplier resource is/can be limited meaning there will inevitably be scenarios where Alerts are missed. Some alerts may be deemed more important than others (depending on the organisation) potentially resulting in a poor service from their Service Provider.</p> <p>Utilising software that is already used in one way or another (Alert Anomaly Detection Thresholds) would make it easier to manage Alerts as they come in, along with helping with any triage completed to prevent further alerts in the future.</p>
Electricity North West	Networks Party	No	<p>No we do not agree.</p> <p>Whilst we wholeheartedly agree with the need for traffic management to be implemented in order to protect both Users and the DCC system from device alert storms we view the proposed solution as too complicated and lacking the overall market intelligence to identify and remediate problematic smart meter models in an efficient manner.</p> <p>It is our view that alert storms in the vast majority of cases are not generated by 'individual' faulty devices but by problems affecting specific manufacturer/model/firmware versions, as such if one variant of meter is affected it is highly likely that large volumes of the same variant meters will also be impacted. This is already evidenced by a known SMETS2 meter model variant which is currently generating millions of incorrect 8014/8015 alerts.</p> <p>Having a system which throttles (discards) a proportion of the alerts at an individual device level goes some way to alleviating the problem but the DCC's focus should be on identifying and resolving root cause by examining device behaviour at the aggregate not the individual device level.</p>

Question 1			
Respondent	Category	Response	Rationale
			<p>We do not see the rationale of opening an incident for each individual device which has been subject to throttling, this simply creates a large burden of work both for the DCC and for end Users and given current issues with SSI performance and usability could possibly render the SSI system unusable. This is highly likely to lead to additional remediation work being required in the SSI and even more cost.</p> <p>Nor do we see any rationale for adding metadata to the % of alerts which have not been throttled in order to inform the User that other alerts have been throttled. Again using the example of the 8014/8015 alerts there are simply too many affected devices for Users to deal with this in this manner. It is another unnecessary cost which offers little value to the end User.</p> <p>We strongly suggest that a simpler approach is adopted by DCC:</p> <ol style="list-style-type: none"> <li>1) The solution should throttle (discard) alerts as currently proposed. We note that DCC already have the mechanism to identify these alerts and therefore the only changes needed are those to discard the unwanted alerts.</li> <li>2) Individual incidents are NOT raised for affected devices</li> <li>3) NO changes to alert metadata or DUIS</li> <li>4) DCC provide a 'day after' report to all parties detailing alert volumes by meter variant (possibly indicating meter variants to which alert throttling has been applied). Parties will use the report to look at alert volumes to identify discrepancies from the expected norm. Having a single report across all parties will help provide a 'total view' and avoid unnecessary duplication of effort</li> </ol>

Question 1																																																																																			
Respondent	Category	Response	Rationale																																																																																
			<p>. e.g.:</p> <table border="1"> <thead> <tr> <th colspan="2"></th> <th colspan="6">Alert volumes received by DCC</th> </tr> <tr> <th colspan="2"></th> <th colspan="2">Installed Devices</th> <th colspan="4">Alert codes</th> </tr> <tr> <th>Manufacturer</th> <th>Model</th> <th>Firmware</th> <th>8nnn</th> <th>..</th> <th>8014</th> <th>8015 ..</th> <th>8F36</th> </tr> </thead> <tbody> <tr> <td>a</td> <td>b</td> <td>c</td> <td>2,000,000</td> <td>200,000</td> <td>8,000,000</td> <td>8,000,000</td> <td>500,000</td> </tr> <tr> <td></td> <td>b1</td> <td>c1</td> <td>10,000</td> <td>1,200</td> <td>40,000</td> <td>40,000</td> <td>2,500</td> </tr> <tr> <td></td> <td></td> <td>c2</td> <td>50,000</td> <td>4,500</td> <td></td> <td></td> <td>12</td> </tr> <tr> <td>..</td> <td>..</td> <td>..</td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>x</td> <td>y</td> <td>z</td> <td>20,000</td> <td>1,800</td> <td>2,400</td> <td>2,400</td> <td>5,000</td> </tr> <tr> <td></td> <td></td> <td>z1</td> <td>50,000</td> <td>6,000</td> <td>6,000</td> <td>6,000</td> <td>12,500</td> </tr> <tr> <td></td> <td></td> <td></td> <td>50,000</td> <td>6,000</td> <td>6,000</td> <td>6,000</td> <td>12,500</td> </tr> </tbody> </table> <p>An aggregated report should also be produced on a weekly and monthly basis.</p> <p>5) The DCC should act as the primary owner of any issues identified and raise problem records to track accordingly – noting that DCC will not be responsible for actual resolution of defects if they are proved to be caused by faulty or non-compliant meters.</p> <p>Such an analytics based approach will enable problematic meter variants to be identified promptly and for corrective action to be taken at an early stage.</p> <p>In addition to identifying meter variants which are generating excess alerts it will also help identify meter variants which are NOT generating expected alerts. Such as known issues where Power Restore (8F36) alerts are not being received when power is restored to devices following a Power Outage (AD1).</p>			Alert volumes received by DCC								Installed Devices		Alert codes				Manufacturer	Model	Firmware	8nnn	..	8014	8015 ..	8F36	a	b	c	2,000,000	200,000	8,000,000	8,000,000	500,000		b1	c1	10,000	1,200	40,000	40,000	2,500			c2	50,000	4,500			12	..	..	..						x	y	z	20,000	1,800	2,400	2,400	5,000			z1	50,000	6,000	6,000	6,000	12,500				50,000	6,000	6,000	6,000	12,500
		Alert volumes received by DCC																																																																																	
		Installed Devices		Alert codes																																																																															
Manufacturer	Model	Firmware	8nnn	..	8014	8015 ..	8F36																																																																												
a	b	c	2,000,000	200,000	8,000,000	8,000,000	500,000																																																																												
	b1	c1	10,000	1,200	40,000	40,000	2,500																																																																												
		c2	50,000	4,500			12																																																																												
..	..	..																																																																																	
x	y	z	20,000	1,800	2,400	2,400	5,000																																																																												
		z1	50,000	6,000	6,000	6,000	12,500																																																																												
			50,000	6,000	6,000	6,000	12,500																																																																												

## Question 2: Will there be any impact on your organisation to implement SECMP0062?

Question 2			
Respondent	Category	Response	Rationale
<b>Bryt Energy</b>	Small Supplier	Yes	Any changes to DUIS and changes to alert management would require internal review. Any new management process and root cause analysis would require additional resources internally where required.
<b>EDF Energy</b>	Large Supplier	Yes	<p>This change would reduce the amount of effort that is required for our systems to process and manage alerts. Ultimately the action we take is going to be the same as the underlying issue generating the alert is the same, but this change will help make it easier to understand and manage any issues on a more timely and cost-effective basis.</p> <p>We anticipate the most significant benefits to come from the DCC, and it would therefore be useful if they could quantify these. It is noted that the risk associated with not making this change is that excess volumes of alerts could cause the DCC systems to fail. The benefit to the DCC of making this change would then be the avoided cost of reinforcing their systems, and procuring additional capacity, in order to deal with the volumes of alerts and meet their SLAs. We would expect the benefits accrued by individual SEC Parties to be relatively small compared to the DCC's avoided costs.</p> <p>Were the DCC not to upgrade their systems to cope with the alert traffic and they were to fail as a result, this would have a significant material impact on us, especially if occurred at a time that meant that smart meters could not be successfully installed and commissioned.</p>
<b>Western Power Distribution</b>	Networks Party	Yes	If this modification is approved it will result in both system and process changes within our organisation.

Question 2			
Respondent	Category	Response	Rationale
			<p>Initially, in order to know if any alerts are being throttled, we will be required to monitor the SSI dashboard and this will mean a change to internal processes.</p> <p>We will then need to develop our systems so that they can receive and interpret the additional message data.</p> <p>Once the DUIS/XSD change has been implemented, we will need to update our back end systems and processes to handle the new information and respond accordingly.</p>
<b>SSEN</b>	Networks Party	No	As these are handled before being delivered into our adapter, no changes are expected to be made.
<b>E.ON</b>	Large Supplier	Yes	<p>E.ON anticipates changes will need to be implemented to our systems and procedures. However, before we can fully answer this question, we have the following points which we seek further clarification:</p> <ol style="list-style-type: none"> <li>1. In Requirement 1 there is reference to an incident being raised where the generic alert threshold of &gt;50 alerts of any type being received from a specific device within a 30 minute period. Which party will that alert be raised against? Is the intention that the alert is raised against the DSP to initiate the device/alert monitoring, or will it be raised against the responsible Supplier to notify them that this threshold has been breached? If raised against the responsible Supplier at this stage, what action are they expected to take?</li> <li>2. In Requirement 1 there is reference to a second incident being raised when the device/specific alert threshold is breached. Who will this incident be raised against? Is the assumption correct that it would be raised against the KRP that would normally be in receipt of that alert? Please confirm.</li> </ol>

Question 2			
Respondent	Category	Response	Rationale
			<p>3. In the Business Requirements document, Requirement 2 – to notify users when alerts have been subject to throttling – may be delivered later than the remaining requirements. E.ON would like to understand an estimated delivery date.</p> <p>4. If the alerts are throttled then we may lose visibility of patterns in SSI that are useful in diagnosing the source of a problem. The proposal would be much stronger if the monitoring and throttling of these alerts was investigated by the DSP to identify these patterns and root causes proactively, instead of raising an Incident against a Supplier. We will need DSP input to diagnose the issue anyway and any additional information that could be added to the incident ticket would be very helpful.</p> <p>5. E.ON would like the DCC to provide more detail on how they would ensure the notifications land with the right Supplier contacts and in a way that highlights the relevant priority in a suitable way.</p>
<b>Npower</b>	Large Supplier	Unknown	
<b>Smartest Energy</b>	Small Supplier	No	
<b>Electricity North West</b>	Networks Party	Yes	If the proposal is approved as it stands then each individual User will have to undertake their own analytics and problem identification even though the likely resolution is a change to the device/firmware variant. This is not an efficient use of resource and DCC are ideally placed to provide such analytics centrally, offering a 'whole system' view.

### Question 3: Will your organisation incur any costs in implementing SECMP0062?

Question 3			
Respondent	Category	Response	Rationale
<b>Bryt Energy</b>	Small Supplier	Yes	Any changes to DUIS and changes to alert management would require internal review and cost. Any new management process and root cause analysis would require additional resources internally where required.
<b>EDF Energy</b>	Large Supplier	Yes	<p>We will need to make changes to our working practices regarding the management of alerts and ensure that these are communicated and relevant training undertaken. We do not anticipate the implementation costs of making this change, especially in Stage 1, to be material as the actions that will be taken as a result of receiving filtered alerts should be the same as they would have been for filtered alerts, as the underlying issue causing the alerts to be sent will not have changed.</p> <p>In the event that a DUIS based solution is implemented the costs are likely to be higher – however we would usually incur a relatively fixed cost for upgrading to a new version of the DUIS, irrespective of the number of changes included in that new release. The technical implementation costs that would be associated with making an individual change such as this one is likely to be low.</p>
<b>Western Power Distribution</b>	Networks Party	Yes	<p>The main cost, beside the modification implementation costs, will be developing the systems to accept and handle the additional information within the alerts.</p> <p>It is difficult to determine exactly how much this modification will cost as it will depend what other changes form part of that particular DUIS/XSD release. There will be additional costs beyond the DUIS/XSD change to develop our back ends systems and processes to handle the additional information we are receiving.</p>

Question 3			
Respondent	Category	Response	Rationale
			<p>If we were to implement this change as a standalone change the cost to our organisation would be approximately £20,000.</p> <p>We will not benefit from any cost savings as a result of this modification.</p>
<b>SSEN</b>	Networks Party	Yes	Due to the implementation plan for this, we are unsure of how you will communicate the volumes of suppressed alerts. We will still have the desire to understand and report on the number of alerts received into our adapter Vs. the amount generated by a device. This will require extra time to gather and report on this information.
<b>E.ON</b>	Large Supplier	Yes	E.ON expects costs will be incurred but cannot evaluate these costs until more information is provided following testing of the proposed solution.
<b>Npower</b>	Large Supplier	Unknown	
<b>Smartest Energy</b>	Small Supplier	No	
<b>Electricity North West</b>	Networks Party	Yes	<p>Changes to DUIS may be required although offering little or no practical benefit.</p> <p>Analytics will need to be developed to identify issues with particular device variants.</p> <p>Organisational changes to deal with significant volumes of incidents.</p> <p>Estimated £100k.</p>

## Question 4: Do you believe that SECMP0062 would better facilitate the General SEC Objectives?

Question 4			
Respondent	Category	Response	Rationale
<b>Bryt Energy</b>	Small Supplier	Yes	<p>While we agree this better facilitates the General SEC Objectives, discussion is required on the SEC impacts this change brings.</p> <p>Obligations rest purely on a SEC User</p> <p>The current solution and SEC assume that the DCC is responsible for passing all alerts though to the SEC User who is responsible</p>
<b>EDF Energy</b>	Large Supplier	Yes	<p>We agree that this change would better facilitate SEC Objective (a) as reducing the volumes of alerts that need to be processed and managed will enable smart metering systems to be managed more efficiently.</p> <p>We do not agree that this change better facilitates SEC Objective (e) as it is not clear how this change would directly impact energy networks, and certainly not facilitate innovation in the design and operation of energy networks.</p>
<b>Western Power Distribution</b>	Networks Party	Yes	<p>We disagree with the proposer's rationale that this modification better facilitates Objective (a) as it does not impact the Smart Metering Systems at Energy Consumer's premises. This change impacts the DSP systems and northbound to the Users systems.</p> <p>We also disagree with the proposer's rationale that this modification better facilitates Objective (e) as it does not facilitate the innovation in the design and operation of the Energy Networks to deliver a secure and sustainable supply of electricity.</p>

Question 4			
Respondent	Category	Response	Rationale
			We do believe that this modification better facilitates SEC Objective (b) as it will ensure that the DCC can fulfil their obligations by providing some additional protection to part of their system.
<b>SSEN</b>	Networks Party	Yes	We believe that this modification better facilitates general SEC Objectives (a) and (e) for the reasons documented in the SECMP0062 Modification Report
<b>E.ON</b>	Large Supplier	Yes	E.ON agrees with the rational proposed in pages 11 and 12 in the Modification Report.
<b>Npower</b>	Large Supplier	Yes	It will protect the DCC infrastructure from overload
<b>Smartest Energy</b>	Small Supplier	Yes	This modification would better facilitate SEC Objective (a) and (e) as this will help improve the operation of Smart Metering Systems with the use of additional precautions alongside the existing detection program in the DSP. This mod also demonstrates innovation in improving between Service Users and the DCC.
<b>Electricity North West</b>	Networks Party	Yes	We support the intent of the modification proposal however we challenge whether the proposed solution results in efficient operation.

## Question 5: Noting the costs and benefits of this modification, do you believe SECMP0062 should be approved?

Question 5			
Respondent	Category	Response	Rationale
<b>Bryt Energy</b>	Small Supplier	Yes	Any DUIS changes would result in impacts and cost, however it is not possible to identify cost at this point until DUIS changes are finalised. Bryt Energy envisages no cost to any Alert Root cause analysis.
<b>EDF Energy</b>	Large Supplier	Yes	Subject to confirmation from the DCC that the benefits that they would accrue as a result of avoiding upgrades to their systems in order to meet their SLAs exceed the costs, we believe that this modification should be approved.
<b>Western Power Distribution</b>	Networks Party	No	We do not believe that this modification will provide an adequate solution to alert volumes and unnecessary traffic, based on what we are currently experiencing. Please see comments in Question 10.
<b>SSEN</b>	Networks Party	No	We feel the costs are acceptable due to the technical changes required to suppress alerts. However, we believe the approach needs further work surrounding devices creating permanent alert storms and the email notification solution for impacted parties.
<b>E.ON</b>	Large Supplier	Yes	As per reasons noted above.
<b>Npower</b>	Large Supplier	Yes	
<b>Smartest Energy</b>	Small Supplier	Yes	As a small supplier resource is/can be limited. Where we have received alert storms in testing, it has proven to be time consuming going through the alerts to identify what the alerts are for. It also means where we may spend time trying to resolve an issue, we can potentially miss more important alerts that may have been received alongside other alerts deemed not as important.

Managed by

Question 5			
Respondent	Category	Response	Rationale
Electricity North West	Networks Party	No	The current proposed solution is too complicated and lacking the overall market intelligence to identify and remediate problematic smart meter models in an efficient manner.

**Question 6: If SECMP0062 is approved, should the solution include the email notification in Stage 1 of the implementation approach? DCC have stated this will occur in every incident event if this is included as part of the solution.**

Question 6			
Respondent	Category	Response	Rationale
<b>Bryt Energy</b>	Small Supplier	Yes	SEC Users should have the option to receive email alerts along with SSI visibility. Email should be managed as per SEC Contacts.
<b>EDF Energy</b>	Large Supplier	No	The likely volume of e-mails is going to be high and just create another problem in managing that traffic. Making the relevant information available via the SSI should be sufficient in Stage 1.
<b>Western Power Distribution</b>	Networks Party	No	We do not feel that the receipt of an email will aid us and will cause additional burden to our resource, especially as there is a likelihood of large volumes.
<b>SSEN</b>	Networks Party	No	Due to the nature of some alert storms, we feel that this could cause administrative issues with the potential volume of emails received.
<b>E.ON</b>	Large Supplier	Yes	E.ON would like to receive email notification in Stage 1 of the implementation approach. Although the incidents will be raised in SSI by default, they may not be picked up immediately if in amongst a much larger volume of incidents already raised by, or against, E.ON. Specific email notification of this type of incident will support quicker review and resolution of the issue.  As noted above, we would like the DCC to provide more detail on how they ensure the notifications land with the right Supplier contacts and in a way that highlights the relevant priority in a suitable way.
<b>Npower</b>	Large Supplier	Yes	Email is necessary to notify the user of the alert

Managed by



Question 6			
Respondent	Category	Response	Rationale
<b>Smartest Energy</b>	Small Supplier	Yes	The solution should include email notification to keep all organisations informed with changes. It also gives the opportunity for the information to be shared/forwarded easily other colleagues at different levels of involvement within Smart Metering and takes away the manual aspect of checking the SSI Dashboard.
<b>Electricity North West</b>	Networks Party	No	Sending emails relating to individual devices is unnecessary and will only create extra complications and cost.

## Question 7: How long from the point of approval would your organisation need to implement SECMP0062?

Question 7			
Respondent	Category	Response	Rationale
<b>Bryt Energy</b>	Small Supplier	We no issue with the proposed timelines for implementation for Bryt Energy	This is dependant on DUIS Changes being notified in advance and root cause analysis being undertaken.
<b>EDF Energy</b>	Large Supplier	1 month	We would need a month in order to be able to amend and train out revised working practices in regards to the management of alerts and use of the SSI.
<b>Western Power Distribution</b>	Networks Party	For the full solution including the DUIS change we would require a minimum of six months lead time.	This is due to the XSD change involved. This time scale allows time for planning the works to uplift the systems to the new DUIS version with appropriate regression testing, as well as additional system functionality to be built and full testing to be undertaken.
<b>SSEN</b>	Networks Party	N/A	As the modification will not result in any changes to our internal systems, we will not require a large lead time.

Question 7			
Respondent	Category	Response	Rationale
<b>E.ON</b>	Large Supplier	Clarification is required before an answer can be submitted.	E.ON anticipates changes will need to be implemented to our systems and procedures. However, before we can fully answer this question we require further information (see queries raised in our response to question 2).
<b>Npower</b>	Large Supplier	Unknown	
<b>Smartest Energy</b>	Small Supplier	N/A	N/A
<b>Electricity North West</b>	Networks Party	Dependent upon whether DUIS changes are mandatory then it would require a 6 month lead time.	Sufficient time is required in order to contract for changes with our own service providers in order to design, develop, test and implement.

## Question 8: Do you agree with the proposed implementation approach?

Question 8			
Respondent	Category	Response	Rationale
<b>Bryt Energy</b>	Small Supplier	No	At present, we do not know the scope or range of alerts
<b>EDF Energy</b>	Large Supplier	Yes	We agree with the proposed implementation approach.
<b>Western Power Distribution</b>	Networks Party	Yes	We believe that it makes sense to implement a solution sooner rather than later to help protect the DSP systems, with a DUIS change following at an appropriate time.
<b>SSEN</b>	Networks Party	No	We are currently receiving in excess of 100,000 device alerts on a daily basis. With the timeline proposed, this will be implemented after a further increase of alert storm devices being enrolled and the migration of SMETS1 devices which could cause capacity issues with our adapter.
<b>E.ON</b>	Large Supplier	Yes	7 November seems a reasonable date to ensure a positive outcome.
<b>Npower</b>	Large Supplier	Yes	Caveat** the list of exempt needs to be fully agreed by all parties
<b>Smartest Energy</b>	Small Supplier	Yes	A two staged approach means that the solution can be provided with care and due diligence.
<b>Electricity North West</b>	Networks Party	No	Please refer to earlier responses

## Question 9: Do you have any Alert Codes that you feel should not be subject to throttling as part of SECMP0062’s solution?

Question 9			
Respondent	Category	Response	Rationale
<b>Bryt Energy</b>	Small Supplier	Yes	<p>As per comment 1, until Identification of alert storms of alerts on the proposed alerts not to be subject to “Throttling”, in which would circumvent the proposed solution is identified it is difficult to say if any alerts should be exempt.</p> <p>Proposals would be safety, theft, commissioning alerts etc. Root cause analysis needs to be undertaken first to understand what alerts are causing potential issues and if they are genuine or defective.</p> <p>For example, if there are only two types of alerts causing an issue, we would assume at implementation only these two would be throttled and the configuration of any other alerts not throttled. DCC would monitor and add or remove based on actual traffic as new devices and firmware enter the market.</p> <p>In terms of implementation we would also welcome a phased implementation approach to ensure robust of the DCC Solution in the Production environment. Initial implementation would be to throttle an anomalous non-critical alert and to measure the DCC solution is fit for purpose, before throttling an critical alert codes.</p>
<b>EDF Energy</b>	Large Supplier	No	<p>We have not identified any at this time. As noted in our response to question 1 a more detailed set of rules as to what constitutes an excess/duplicate alert will need to be defined to ensure that alerts are not unnecessarily filtered where they relate to multiple re-occurring issues rather than a single ongoing issue.</p>
<b>Western Power Distribution</b>	Networks Party	No	

Question 9			
Respondent	Category	Response	Rationale
SSEN	Networks Party	No	We believe that all codes should be subject to throttling based on the time and volume parameters that are being implemented.
E.ON	Large Supplier	Yes	<p>E.ON believes that there is more insight to be gained by having the raw data and alerts sent with appropriate time stamps.</p> <p>If the alerts are throttled then visibility of patterns that are useful in diagnosing the source of a problem is lost. The proposal would be much stronger if the monitoring and throttling of some alerts was done in partnership with the DSP to identify patterns and thus potential root causes.</p> <p>There is recognition that a pragmatic approach is required though our preferred method is that all data is passed.</p> <p>Any alerts relating to device / supply power loss, removal of covers or batteries (gas meters) should NOT be throttled.</p> <p>The following Alert Codes should not be subject to throttling as they highlight potential or actual Health and Safety events;</p> <p>0x8F77 Unauthorised Physical Access - Second Terminal Cover Removed</p> <p>0x8F76 Unauthorised Physical Access - Terminal Cover Removed</p> <p>0x8F74 Unauthorised Physical Access - Meter Cover Removed</p> <p>0x8F73 Unauthorised Physical Access - Battery Cover Removed</p> <p>0x8F3F Unauthorised Physical Access - Tamper Detect</p> <p>0x8F1F Low Battery Capacity</p> <p>0x8F1D GSME Power Supply Loss</p> <p>0x81C0 Supply Disconnect Failure</p>

Managed by



Question 9			
Respondent	Category	Response	Rationale
<b>Npower</b>	Large Supplier	Yes	These need to be in full agreement of all users
<b>Smartest Energy</b>	Small Supplier	No	All Alert codes should be subject to throttling to help identify common trends that trigger the alert storms. It will also help determine if intervention from specific parties is needed or need to be made aware of. This should help prevent the wrong actions being taken and potentially break systems/meters.
<b>Electricity North West</b>	Networks Party	Yes	Power Outage (AD1), Power restore (8F35 and 8F36) should not be throttled.

## Question 10: Please provide any further comments you may have

Question 10		
Respondent	Category	Comments
Bryt Energy	Small Supplier	None
EDF Energy	Large Supplier	No
Western Power Distribution	Networks Party	<p>Whilst we understand the idea behind this proposal, we are concerned that this solution will not prevent high volumes of unnecessary alerts and does not address the issue as to why devices are generating alerts in such high volumes.</p> <p>We have undertaken a review of 'nuisance' alerts that we are currently receiving, alongside this modification's proposed solution. Currently we are receiving extremely high volumes of two specific alerts, (doubling every month with over 9,000,000 expected for April), however, due to the number of devices generating these alerts, this solution would not actually prevent any of these alerts from coming through to us.</p> <p>We believe that there should be further discussions to fully understand the problem that the DCC are trying to resolve. We don't believe, based on what we are seeing on our systems, that the solution and parameters described in this modification will result in adequate protection.</p>
SSEN	Networks Party	It is disappointing that this implementation approach was favoured above a firmware update approach as discussed in the first working group. Based on the volumes and time periods this will eradicate most alerts we receive, however based on the current level of Power Factor alerts we receive (around 200 every 5 minutes) we will still receive multiple alerts daily. This also prevents us for supporting the implementation of an email notification.

Question 10		
Respondent	Category	Comments
E.ON	Large Supplier	See above
Npower	Large Supplier	
Smartest Energy	Small Supplier	
Electricity North West	Networks Party	<p>As describe above the modification should focus on identifying root cause issues by evaluating traffic as a whole across device variants.</p> <p>Raising individual device incidents and treating each as a separate issue is neither manageable nor in the best economic interests of customers. Focus should be on the aggregate impact across the DCC system and all Users as a whole.</p>

This document is classified as **White** in accordance with the Panel Information Policy. Information can be shared with the public, and any members may publish the information, subject to copyright.

# SECMP0062 ‘Northbound Application Traffic Management - Alert Storm Protection’


## Annex F

### First Modification Report Consultation responses

#### About this document

This document contains the full non-confidential collated responses received to the first SECMP0062 Modification Report Consultation.

#### Summary of responses



## Question 1: Do you believe that SECMP0062 should be approved?

Question 1			
Respondent	Category	Response	Rationale
Western Power Distribution	Electricity Network Party	Reject	<p>Western Power does not believe that this modification as it stands better facilitates the SEC Objectives.</p> <p>The MRC states that the Proposer believes that it better facilitates SEC Objective (a) and (e). We cannot see any correlation to SEC Objective (e) 'to facilitate such innovation in the design and operation of Energy Networks (as defined in the DCC Licence) as will best contribute to the delivery of a secure and sustainable Supply of Energy.'</p> <p>We believe that the intent of this modification would be to better facilitate SEC Objective (f), to ensure the security of Data and Systems, however we do not believe that the solution proposed will do this.</p> <p>To help justify our response we have considered this modification against today's scenario. We are currently receiving over 1.3 million nuisance alerts (8014 and 8015) a day. If this solution was implemented it would not actually suppress any of these due to their frequency.</p> <p>Also, if the solution did create incidents, as the Target Recipient we would be getting incidents assigned to us, however we have absolutely no control over these alerts and so would have to use resource to respond to incidents advising that there is nothing we can do to stop the issue.</p>

Question 1			
Respondent	Category	Response	Rationale
			<p>Finally in the WGC a recommendation was proposed that the Unauthorised Physical Access alerts (including 8F3F) be exempt. We believe that this is reasonable due to Health and Safety concerns, however if this was the case, the current issues that the DCC are experiencing would continue and the issue remain as none of the current nuisance alerts would be disregarded.</p> <p>In conclusion we do not believe that the proposed solution, as it currently stands, better facilitates any SEC Objective, nor resolves the issue outlined in the background of the Modification Report Consultation as it does not address the root causes of the high volumes of these alerts.</p>
<b>EDF Energy</b>	Large Supplier	Approve	We believe that SECMP0062 better facilitates SEC Objective (a) as minimising the impact of 'alert storms' will ensure that the DCC systems do not become overloaded and continue to support communications with smart metering devices. It will also prevent DCC User systems from receiving unnecessary duplicate alerts, enabling actual problems to be more easily identified and rectified.
<b>Electricity North West Limited</b>	Electricity Network Party	Reject	<p>We support the intent of the modification proposal, however, we challenge whether the proposed solution results in efficient operation as per Objective (a) or innovation in operation as per Objective (e).</p> <p>The key reasons for our rejection of this modification are as follows:</p> <ul style="list-style-type: none"> <li>a) The proposed solution would do nothing to filter the 8014/8015 Power Factor alerts (number two issue in terms of volume on the SECOPS list of nuisance alerts). The proposed DCC solution would only filter alerts happening at a rate of more than 2 per minute per device. 8014/8015 are spurious alerts being incorrectly generated by non-compliant SMETS2 meters when power consumption falls to or returns from</li> </ul>

Managed by



Question 1			
Respondent	Category	Response	Rationale
			<p>a very low threshold and as such we could receive one every 5 minutes or every half hour e.g. when a fridge compressor in an empty premise kicks on and off. To date we have received circa half a million of these alerts from just a few hundred devices.</p> <p>b) The modification does not identify or address root cause of alert storms which are in our belief primarily caused by non-compliant meter devices rather than by individual device behaviour. As part of this SEC modification DCC should look to provide MI/Analytics based reporting which will pro-actively identify the manufacturer/model/firmware combinations of meters that result in alert storms such that appropriate action can be taken by suppliers/manufacturers to resolve/remediate the root causes.</p> <p>c) Each individual meter affected by the proposal could result in hundreds, if not thousands, of incidents being raised in the DCC Incident Management System. Each time throttling is initiated for an individual device it will generate an incident in the DCC Incident Management System, this would have a clear knock on-impact in terms of DCC and User resource in order to update and resolve/close the incidents and therefore a likely increase in both DCC and User resource costs. There is no assessment by DCC of consequential cost and resource impacts required to manage the increased volumes of incidents. There is also no mention of how DCC would propose to use problem management to collate and resolve the numerous incidents (as per standard ITIL process) and address root cause.</p> <p>d) DCC are proposing that the incidents would be assigned to the intended alert recipient, not to the party responsible for the meter/configuration. As a DNO we can do little or nothing to prevent further alerts or to resolve issues with non-compliant</p>

Question 1			
Respondent	Category	Response	Rationale
			<p>meter functionality, we have no commercial or contractual relationship with Suppliers or Manufacturers.</p> <p>e) DCC are proposing to build email functionality to send an email each time throttling is initiated for an individual device. Although DCC are proposing to allow Users to individually choose whether switch this functionality on or off this would clearly result in huge volumes of email traffic which would impact on DCC and User email infrastructure. There is no assessment by DCC of consequential infrastructure costs required to manage increased volumes of emails.</p> <p>f) DCC are proposing to amend DUIS functionality so that subsequent alerts which are not throttled would include metadata to indicate that alerts were previously throttled and to provide a counter of the number of throttled alerts in real-time. It is unclear what the business use case for this requirement is and what action could actually be taken in real-time to remediate any affected devices. A DCC reporting/MI system could provide the same information without requiring each User to make any amendments to their DUIS interface.</p> <p>g) DCC have not provided any modelling to show what the solution outputs would actually result in e.g. 10k meters each generating 10 alerts, throttled as 1 in 10 could theoretically result in 10k incidents and 10k emails dependent upon the timing/interval between the alerts being received by DCC.</p>
<b>SSEN</b>	Electricity Network Party	Reject	SSEN support the overall requirement to suppress alert storms to protect the DCC and user systems. From the previous consultation, SSEN still challenge whether the proposed changes will adequately deliver the required solution.

Question 1			
Respondent	Category	Response	Rationale
			<p>Our concerns still surround the suppression logic. As we have not seen the worked example as described in the consultation, we are unable to understand the true impact on SSEN and our adapter. Looking to the initial proposed configuration parameters, in this consultation, this will still allow many alerts through to our adapter.</p> <p>We also have concerns around the proposed SSI Dashboard, reporting and email notification functionality. As previously stated we would want to be able to understand the number of alerts throttled without this having a negative impact on SSI, our internal systems and processes. The proposed solution does not allow for an appropriate mechanism to notify us, manage and report on throttling without internal processes created to handle this.</p> <p>It is also proposed to introduce DUIS schema changes to provide real time notification of alert throttling. SSEN are unclear as to why this would be required if the throttling is already handled by a new mechanism within the DCC.</p>
Security Sub-Committee	Other Respondent	Approve – subject to security concerns being satisfactorily addressed.	<p>The Consultation Report contains a statement:</p> <p><b>“Sub-Committee views</b></p> <p>The Security Sub-Committee (SSC) chairman was on the Working Group and attended one of the meetings when the business requirements were being formulated. The view provided on behalf of the SSC at the time was that this shouldn’t hold any security risks provided the proposed solution adheres to the requirements put forward.”</p> <p>This does not represent clearly enough the SSC view. The SSC view is firmly that security alerts should not be throttled or discarded. The notes from the Working Group 2 show:</p> <p>“An SSC member raised concern over the alert types being throttled in the Working Group meeting, citing security implications. The Working Group took note of these concerns and</p>

Question 1			
Respondent	Category	Response	Rationale
			<p>highlighted in the drafted Business Requirements where this had been taken into account and would be consulted over with the rest of the Working Group.”</p> <p>I request that the entry for the Sub-Committee views be amended to:</p> <p><b>“Sub-Committee views</b></p> <p>The Security Sub-Committee (SSC) chairman was on the Working Group and attended one of the meetings when the business requirements were being formulated. The view provided on behalf of the SSC was that security alerts should not be restricted. A solution could be supported where a list of exempted security-related Alerts that will not be subject to throttling or subject to a different level of throttling can be approved by the SSC and for SSC to receive regular reports.”</p>
Northern Powergrid	Electricity Network Party	Reject	<p>We wholeheartedly support the intent of the modification proposal; however we are concerned that the proposed solution may only filter out some, but not all, nuisance alerts. Our concern is partly based upon:</p> <ul style="list-style-type: none"> <li>• The initial configuration parameters included in the Modification Proposal. If these parameters were to be adopted then, at a device level, three nuisance alerts every two minutes could be generated by rogue devices without then being discarded.</li> <li>• If our understanding is correct then, a rogue device could generate 2,160 nuisance alerts per day (3x30x24) without them being discarded. At this rate, across a population of say 1,000 meter sets this would see a User Party receiving over 2 million nuisance alerts per day.</li> <li>• The modification does not identify or address what we believe to be the root cause of nuisance alerts. We believe that the primary driver behind nuisance alerts is that device sets that haven’t been tested with sufficient rigour before being deployed into the DCC’s production environment. We note, for example, that no devices have</li> </ul>

Question 1			
Respondent	Category	Response	Rationale
			<p>yet passed all SMDA tests. In this context we consider it likely that device sets will continue to be deployed in the DCC production environment that will generate significant volumes of nuisance alerts.</p> <ul style="list-style-type: none"> <li>• If the ‘active notification being given to Users when the Alerts are being controlled’ is undertaken on a per device basis, or is somehow based upon the number of nuisance alerts being discarded, then a very ‘chatty’ device set cohort could generate an enormous volume of incidents for Users or the DCC to manage, which could act as an unwelcome distraction from the day-to-day operation of their respective businesses.</li> </ul> <p>Our view therefore, is that any solution that is implemented should:</p> <ul style="list-style-type: none"> <li>• Through a SEC modification or similar industry change, mandate those parties responsible for bringing new device sets into the DCC production environment to undertake more rigorous testing of such device sets prior to their deployment, and provide an evidence based affirmation outlining why they believe such sets are fit for such deployment.</li> </ul> <p>If an alert ‘filtering’ / discarding solution is employed then it should:</p> <ul style="list-style-type: none"> <li>• Be capable of filtering out the 8014/8015 Power Factor alerts (the nuisance alerts that thus far have been the most problematic for DNOs and against which the DNOs will assess the suitability of any proposed solution). The initial configuration parameters of the proposed solution may not filter out the 8014/8015s that are currently causing problems for DNOs.</li> <li>• Generate an output for User Parties, perhaps via report or another form of management information, which provides an easy to consume view of device sets (manufacturer/model/firmware combinations) generating high volumes nuisance</li> </ul>

Question 1			
Respondent	Category	Response	Rationale
			<p>alerts. In tandem with this a complementary report could also be provided that provides details of the remediation progress of responsible parties.</p> <p>With regards to alert 'filtering' and/or discarding, we are mindful that this proposal runs counter to the idea that the DCC is, at its heart, a message processing, execution and transmission organisation, and that it does not interfere with or otherwise manipulate message delivery. This view, that the DCC is primarily a message delivery service, is an idea that the DCC has itself emphasised in the past. If a message filtering precedent is therefore established via this, or any other SEC modification proposal, it is important that strong governance and oversight arrangements are put in place to ensure that filtering is only ever used where it is in the best interests of all relevant stakeholders, especially energy consumers.</p>
<b>Npower</b>	Large Supplier	Approve	We support the proposers views and believe that this change to the SEC will reduce the likelihood of DCC overload due to alert storms.
<b>Scottish Power</b>	Large Supplier	Neutral	<p>While we would welcome the beneficial effects of implementing SECMP0062, we are very concerned about projected costs that appear to us as excessive.</p> <p>Moreover, we note that the SECMP0062 solution would effectively deliver a level of functionality that Users were already given to expect of the DCC's basic design. Therefore, we are of the view that the costs to implement should already have been factored into the DCC's business plan and that there should be no question of these costs now being passed on separately to the DCC's Users.</p> <p>At high volumes, alert storms have a detrimental impact on User system performance and server capacity. They have been consistently highlighted as an issue, ever since the DCC UIT-A network was first brought down by a small number of alerting devices circa two years ago.</p>

Question 1			
Respondent	Category	Response	Rationale
			<p>While this traffic management solution does not address the root cause, it will at least help to buffer User systems from potentially large volumes of nuisance alerts and alerting behaviour until an enduring solution can be put in place. As such we agree that this modification broadly supports General SEC Objectives (a) and (f).</p> <p>However, we note that the solution only mitigates the problem of alert storms when such messages are at the point of delivery to the DSP. We would assume, then, that the volume of messages is likely to remain high for the CSP and, unless further measures were to be taken, could once again become problematic over time.</p> <p>Therefore, while we are very concerned about the costs of SECMP0062, these concerns are compounded by the risk that SECMP0062 may not represent an effective long term solution.</p>

## Question 2: Please provide any further comments you may have

Question 2		
Respondent	Category	Comments
Western Power Distribution	Electricity Network Party	
EDF Energy	Large Supplier	
Electricity North West Limited	Electricity Network Party	<p>The main reason for rejecting the proposal is primarily it does nothing to mitigate a major issue which is currently affecting DCC and Users alike.</p> <p>An alternative solution could be for DCC to identify the manufacturer/model/firmware variants of meters which are causing alert storms and then agree with each individual Users as to whether they wish to either fully suppress particular type of alerts or let 1 in 'n' alerts through. e.g. they could ask DNO's do you want the 8014/8015 alerts from manufacturer/model/firmware = 'X' and we would decline because we know they originate from a non-compliant device.</p>
SSEN	Electricity Network Party	<p>SSEN as previously stated, are concerned that this implementation approach does not address the root cause of the alert storms issue. Based on the volumes and time periods proposed in this consultation, we agree this will suppress some alerts. However, based on the current rate of Power Factor alerts we receive, it is estimated that we will still receive large volumes of alerts daily. Due to this we are unable to support this SEC Mod.</p>
Security Sub-Committee	Other Respondent	
Northern Powergrid	Electricity Network Party	We have no further comments.

Question 2		
Respondent	Category	Comments
<b>Npower</b>	Large Supplier	An improvement to this proposal would have been to enable user specific configuration. By not having user specific configuration, controls can't be put in place that meet the specific needs of suppliers who may use differing configuration on the devices, or who may want to see differing levels of alert volumes.
<b>Scottish Power</b>	Large Supplier	We note that the 8f3e alerts from the GPF are only an issue for the Telefonica hubs. The defect on the EDMI hub where no 8f3e are generated by that hub will not be implemented due to loss of connection when the fix is in place. We think this lack of consistency in how the three hubs implement the 8f3e specification is something that needs to be addressed in the longer term; perhaps through a solution that manages the throughput of such alerts at the CH itself.

This document is classified as **White** in accordance with the Panel Information Policy. Information can be shared with the public, and any members may publish the information, subject to copyright.

# SECMP0062 ‘Northbound Application Traffic Management - Alert Storm Protection’


## Annex G

# Second Modification Report Consultation responses

### About this document

This document contains the full non-confidential collated responses received to the second SECMP0062 Modification Report Consultation.

### Summary of responses



## Question 1: Do you believe that SECMP0062 should be approved?

Question 1			
Respondent	Category	Response	Rationale
Electricity North West Limited	Electricity Network Party	Reject	<p>We do support the intent of the change proposal but challenge the complexity and cost of the solution.</p> <p>The main reasons for rejection are as follows:</p> <ul style="list-style-type: none"> <li>• The modification does not identify or address root cause of alert storms which we believe are primarily caused by non-compliant meter devices rather than by individual device behaviour. As part of this SEC modification DCC should look to provide MI/Analytics based reporting which will pro-actively identify the manufacturer/model/firmware combinations of meters that result in alert storms such that appropriate action can be taken by suppliers/manufacturers to resolve/remediate the root causes</li> <li>• Each individual meter affected by the proposal could result in hundreds, if not thousands, of incidents being raised in the DCC Incident Management System. Each time throttling is initiated for an individual device it will generate an incident in the DCC Incident Management System, this would have a clear knock on-impact in terms of DCC and User resource to update and resolve/close the incidents and therefore a likely increase in both DCC and User resource costs. There doesn't seem to be an assessment by DCC of consequential cost and resource impacts required to manage the increased volumes of incidents or how DCC would propose to use problem management to collate and resolve the numerous incidents (as per standard ITIL process) and address the root cause</li> <li>• DCC are proposing that the incidents would be assigned to the intended alert recipient, not to the party responsible for the meter/configuration. As a DNO we can do little or</li> </ul>

Question 1			
Respondent	Category	Response	Rationale
			<p>nothing to prevent further alerts or to resolve issues with non-compliant meter functionality, we have no commercial or contractual relationship with Suppliers or Manufacturers</p> <ul style="list-style-type: none"> <li>• DCC are proposing to build email functionality to send an email each time throttling is initiated for an individual device. Although DCC are proposing to allow Users to individually choose whether switch this functionality on or off this would clearly result in huge volumes of email traffic which would impact on DCC and User email infrastructure. DCC doesn't seem to have assessed the impact of consequential infrastructure costs required to manage increased volumes of emails</li> <li>• DCC are proposing to amend DUIS functionality so that subsequent alerts which are not throttled would include metadata to indicate that alerts were previously throttled and to provide a counter of the number of throttled alerts in real-time. It is unclear what the business use case for this requirement is and what action could be taken in real-time to remediate any affected devices. A DCC reporting/MI system could provide the same information without requiring each User to make any amendments to their DUIS interface</li> <li>• DCC has not provided any modelling to show what the solution outputs would result in e.g. 10k meters each generating 10 alerts, throttled as 1 in 10 could theoretically result in 10k incidents and 10k emails dependent upon the timing/interval between the alerts being received by DCC.</li> </ul>
<b>EDF Energy</b>	Large Supplier	Approve	<p>We agree that SECMP0062 better facilitates SEC Objective (a) as managing the volume of alerts being passed through the DCC systems and to DCC Users will support the efficient operation of smart meters.</p> <p>For the avoidance of doubt we believe that SECMP0062 is neutral against the other SEC Objectives, including (e) as this Modification Proposal does not relate to energy networks but to the DCC's communications network.</p>

Question 1			
Respondent	Category	Response	Rationale
Northern Powergrid	Electricity Network Party	Reject	<p>We wholeheartedly support the intent of the modification proposal; however we remain concerned that this revised proposal may only filter out some, but not all, nuisance alerts.</p> <p>Our concern is based upon the likelihood that if the total number of alerts generated is only at an “amber” level these will continue to be passed on to Request Management and hence received by Users.</p> <p>In addition, the proposed change to DUIS, the SSI, and the potential use of emails to communicate “red” threshold anomaly events and incidents, appears to make this a very complex and expensive change.</p> <p>We also remain concerned that this change does nothing to address the device issues that are the root cause of this problem.</p> <p>The MRC states that the Proposer believes that this change better facilitates SEC Objectives (a) and (e). We do not believe that this change supports SEC Objective (e) ‘to facilitate such innovation in the design and operation of Energy Networks (as defined in the DCC Licence) as will best contribute to the delivery of a secure and sustainable Supply of Energy’ because this proposal is primarily attempting to address the symptoms of a problem rather than the root cause.</p>
Western Power Distribution	Electricity Network Party	Reject	<p>Western Power Distribution does not believe that this modification, as it stands, better facilitates the SEC Objectives.</p> <p>The Modification Report Consultation states that the Proposer believes that this modification better facilitates SEC Objective (a) and (e). We don’t agree that this modification would better facilitate SEC Objective (a) by ensuring an efficient operation of Smart Metering Systems as we don’t feel that it fully addresses the problem.</p>

Question 1			
Respondent	Category	Response	Rationale
			<p>We disagree that this modification better facilitates SEC Objective (e) as we do not feel that it facilitates Network Operators in innovating the design and operation of their networks to ensure a secure and sustainable supply of energy.</p> <p>We believe that the intent of this modification would be to better facilitate SEC Objective (f), to ensure the security of Data and Systems, however we do not believe that the solution proposed will do this.</p>
<b>E.ON</b>	Large Supplier	Approve	The revised proposal addresses most of the concerns raised satisfactorily.
<b>SSEN</b>	Electricity Network Party	Reject	<p>SSEN support the overall requirement to suppress alert storms to protect the DCC and user systems. From the previous consultations, SSEN still challenge whether the proposed changes will adequately deliver the required solution.</p> <p>Our concerns still remain around the suppression logic, without seeing a worked scenario that covers for example, 8014 &amp; 8015 alert traffic. Looking to the initial proposed configuration parameters for phase 1 in this consultation, these parameters will still allow 100% of alert storms through to our adapter based on SSEN's current 8014 &amp; 8015 alert volumes. When phase 2 is implemented, we are also unable to understand the impact this will have, as the parameters per alert are a global value. As we are unsure on other parties' requirements we remain unsure on what this value will be set at to understand its impacts on SSEN.</p> <p>We also have concerns around the proposed incident and email notification functionality. As previously stated SSEN would require the ability to understand the number of alerts throttled and incidents raised, without this having a negative impact on the SSI usability, internal systems and processes. The proposed solution does not allow for an appropriate mechanism to notify parties and manage throttling incidents without additional processes created to handle this. Due to current incident volumes within SSI, we require the</p>

Question 1			
Respondent	Category	Response	Rationale
			notification functionality to be set to on to manage our incidents. Although a daily email will now be sent rather than individually per each throttling period, as this is on a per device basis this is still an unsuitable solution.
<b>Centrica</b>	Large Supplier	Approve	Implementation of SECMP0062 will not resolve the issues that the DCC and DCC Users are experiencing with alert storms. However, it will provide some assistance to the DCC and users in controlling, and reducing, the large volumes of nuisance alerts being experienced. We therefore agree that this modification does, to some limited extent, help to better achieve both General SEC Objectives (a) and (f).

## Question 2: Please provide any further comments you may have

Question 2		
Respondent	Category	Comments
<b>Electricity North West Limited</b>	Electricity Network Party	<p>This change proposal introduces additional overheads and potential capacity issues for incident management and email systems for which there is no impact assessment, which could result in additional costs. Additionally, it does not try and analyse and remedy root cause issues which are highly likely to be SMETS2 compliance issues affecting tens of thousands of devices.</p> <p>We feel at this stage that it may be prudent for DCC to target the bare minimum functionality to restrict the alerts as described by the modification. A simple (after the fact) reporting mechanism could then be made available to parties via the existing DCC SharePoint – DCC already use this mechanism to provide weekly inventory reports to parties. Consequently, all other functionality including email, SSI and DUIS changes would be placed on hold and the requirements reviewed by parties 'x' months after the initial implementation has been operating. Only at that time should further changes be assessed when parties and the DCC can then reflect upon the effectiveness of the initial change.</p>
<b>EDF Energy</b>	Large Supplier	<ul style="list-style-type: none"> <li>• We recognise that the volumes of alerts that are being sent in the first place need to be looked at and potentially addressed. Such a device based solution will, however, take some time to not only include within the Technical Specifications (specifically the GBCS) but to implement within devices. SECMP0062 represents a pragmatic and timely solution to the immediate problems DCC and Users are facing in relation to alert volumes.</li> <li>• While we support this Modification Proposal we do have a couple of comments:</li> <li>• It is not clear from the Modification Report consultation what will happen once part 2 is implemented and changes are made to the DUIS to enable notifications to be sent. DCC Users will have different upgrade paths and it may be some time after November 2020 that they upgrade to the new version of the DUIS introduced in the November 2020. Release. We would welcome confirmation that the e-mail/SSI based solution introduced in Part 1 still be available to Users that have not upgraded to the new version of DUIS</li> </ul>

Question 2		
Respondent	Category	Comments
		<p>after the November 2020 release has been implemented. We note that the proposed new legal text for Section H3.14 and Appendix AB (Service Request Processing Document) does not differentiate between versions of DUIS in regards to the obligations the DCC is required to meet.</p> <ul style="list-style-type: none"> <li>The proposed new Section 17.8 refers to the recipient(s) identified in the Response or Alert being informed when the rate of Alerts falls below the Threshold, however it does not state that there will be a notification to those recipient(s) when the rate of Alerts goes above the Threshold in the first place and initiates Alert consolidation. We assume that this is an oversight, a reference to the recipient(s) being notified (which we assume would be either via the DUIS or via email/SSI as) should be included in the text.</li> </ul>
<b>Northern Powergrid</b>	Electricity Network Party	We have no further comments.
<b>Western Power Distribution</b>	Electricity Network Party	<p>Whilst we agree that it is sensible to have some protection for the DSP in the event of extreme circumstances, we question if this is the best solution. We have concerns that this solution is potentially not addressing the root cause. This has also been confirmed by evidence that we have seen in the north where the CSP is currently unable to cope with the alert volumes and therefore we again ask why this modification isn't addressing the root cause of the problem, i.e. 'Alert Storm Protection' in general rather than 'DSP Protection'.</p> <p>We stand by our response to the previous Modification Report Consultation, that the parameters that are provided (which remain the same as previously consulted upon) are not fit for purpose. If this solution had been implemented when we were receiving our highest volume of nuisance alerts (in excess of 2 million 8014 and 8015 a day), it would not have suppressed any alerts being sent through to us.</p> <p>On numerous occasions we have requested that the DCC provide detailed evidence that clearly shows the exact impact that they would see as a result of this modification. To date we have yet to see this, and therefore we have no evidence as to how this modification will benefit them. As a result we can only base our views on our own evidence and experiences.</p>

Question 2		
Respondent	Category	Comments
		<p>We also seek clarification as to how the solution will protect the DSP if their capacity is breached and Devices are continuing to send Exempted Alert Codes?</p> <p>The Modification Report Consultation states that DCC are required to update the Self-Service Interface (SSI) Baseline Requirements Document to align with the requirements of this Modification. Whilst we understand that this document is not part of the SEC, without this information we cannot fully understand and comment on the solution in its entirety.</p> <p>In the legal text, Appendix AB 'Service Request Processing Document' 17.9 states 'any changes to this document shall be prepared and consulted upon by the DCC and approved by the Panel'. Whilst we agree that the DCC shouldn't be able to just amend the parameters without appropriate controls, we question how the DCC would be able to react quickly in the event of an issue arising and these parameters being unsuitable.</p> <p>We are concerned with how this modification has progressed with the DCC having already released code into the production environment that is just waiting to be turned on. It feels like Parties are being forced to approve a modification that the DCC have decided to design build and implement before approval. We feel that the modification process and/or DCC's change process needs to be reviewed in light of this.</p> <p>We seek clarification on how the costs have been calculated. The costs quoted in the Modification Report Consultation state estimated implementation costs of £1,088,392, however the code has already been released into production. Surely this should mean that the costs are final? Are SEC Parties paying for the work already undertaken as well as further costs? What happens if this modification is rejected, are Parties expected to pay for all the work already undertaken in developing and implementing the code?</p> <p>In conclusion, we don't feel that we can support this modification as it stands at this time.</p>
<b>E.ON</b>	Large Supplier	
<b>SSEN</b>	Electricity Network Party	N/A

Managed by



Question 2		
Respondent	Category	Comments
Centrica	Large Supplier	<p>As previously stated, SECMP0062 is not the solution to alert storms but merely a mitigation tool that can be used to suppress the impact. For this modification proposal to be approved we would expect that there is commitment from the DCC and DCC Users to ensuring that the following are achieved:</p> <ul style="list-style-type: none"> <li>• DCC to commit to resolving nuisance alerts caused Communication Hubs by developing and issuing suitable firmware fixes or the ability for such alerts to be suppressed if not fixable via firmware (e.g. hardware design issues that are causing alerts to be generated such as misuse of ports);</li> <li>• Users to ensure that device manufacturers apply similar fixes to devices that are generated alert storms. As with Communication Hubs, where this is due to hardware design, and not resolvable retrospectively, DCC should have the ability to suppress such alerts;</li> <li>• Users, and specifically those that are members of the Smart Metering Device Assurance Scheme (SMDA), to investigate whether alert storms can be detected through device combination testing to avoid such issues only be realised once in the live production environment;</li> <li>• Actual devices to be used in PIT and SIT testing, instead of emulators, to ensure that alert storms can be identified prior to devices / firmware being released into the production environment.</li> </ul>